



UL International (Netherlands) B.V.
Westervoortsedijk 60,
6827 AT Arnhem,
The Netherlands



Member of
EOTA
www.eota.eu

designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, www.eota.eu)

European Technical Assessment

ETA 23/0057
of 13/10/2023

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: UL International (Netherlands) B.V.

Trade name of the construction product

Mulcol® Multimortar

Product family to which the construction product belongs

Fire Stopping and Sealing Product:
• Penetration Seals

Manufacturer

Mulcol International BV
PO Box 93
4330 AB Middelburg
The Netherlands

Manufacturing plant(s)

L/002

This European Technical Assessment contains

272 pages including 3 Annexes which form an integral part of this assessment.

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of

EAD 350454-00-1104

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

I.	SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT	3
1.	Technical description of the product	3
2.	Specification of the intended uses of the product in accordance with the applicable European Assessment Document (hereinafter EAD): EAD 350454-00-1104	3
3.	Performance of the product and references to the methods used for its assessment	5
4.	Assessment and Verification of Constancy of Performance (hereinafter AVCP) applied, with reference to its legal base	6
5.	Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD	6

Annex - Resistance to Fire Classification - Mulcol® Multimortar

Annex A - Flexible and rigid walls	13
Annex B - Rigid floors	127
Annex C - General	263

I. SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT

1. Technical description of the product

- 1) Mulcol® Multimortar is a gypsum based mortar material, used to reinstate the fire resistance performance of wall and floor constructions where they have been provided with apertures for the penetration of single or multiple services.
- 2) Mulcol® Multimortar is supplied as a dry material and is mixed with water to the required ratio prior to installation.
- 3) Mulcol® Multimortar when mixed is self-supporting in a wall and floor orientation and may be used with or without a permanent mineral fibre backing material, depending up the required application and classification (see Annex A/B/C). The products below can be used in conjunction with Mulcol® Multimortar. These products are subject to separate ETAs.
 - Mulcol® Multimastic SP, firestop mastic
 - Mulcol® Multimastic FB, firestop board
 - Mulcol® Multicollar Slim, universal fire collar
 - Mulcol® Multiwrap, fire wrap
 - Mulcol® Multisealant GR, firestop intumescent graphite
 - Mulcol® Multitherm Bandage, thermal insulation
 - Mulcol® Multidisc, firestop disc
- 4) The applicant has submitted a written declaration that Mulcol® Multimortar does not contain substances which have to be classified as dangerous according to Directive 67/548/EEC and Regulation (EC) No 1272/2008 and listed in the "Indicative list on dangerous substances" of the EGDS - taking into account the installation conditions of the construction product and the release scenarios resulting from there.

In addition to the specific clauses relating to dangerous substances contained in this European technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

2. Specification of the intended uses of the product in accordance with the applicable European Assessment Document (hereinafter EAD): EAD 350454-00-1104

Detailed information and data is given in Annex A, B and C.

- 1) The intended use of Mulcol® Multimortar is to reinstate the fire resistance performance of flexible wall, rigid wall and floor constructions where they are penetrated by various services.
- 2) The specific elements of construction that the system Mulcol® Multimortar may be used to provide a penetration seal in, are as follows:
 - a) Flexible walls*: The wall must have a minimum thickness of 100 mm.
 - b) Rigid walls*: The wall must have a minimum thickness of 100 mm and comprise concrete, aerated concrete or masonry, with a minimum density of 400 kg/m³.
 - c) Rigid floors: The floor must have a minimum thickness of 150 mm and comprise aerated concrete or concrete with a minimum density of 400 kg/m³.

* See Annex C for the field of application.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.
- 3) The system Mulcol® Multimortar may be used to provide a penetration seal with services e.g. cables, cable trays, metal pipes, composite pipes and plastic pipes, with and without insulation, with mixed services within the same seal/aperture (for details see Annex A and B).
- 4) The Mulcol® Multimortar may be used to seal apertures in separating elements up to a maximum seal size given in Annex C. The minimum permitted separation between adjacent seals/apertures is 100 mm. Where seals are installed without services (blank), precautions need to be taken to prevent a person stepping onto a horizontal seal or falling onto a vertical seal.
- 5) The provisions made in this European Technical Assessment are based on an assumed working life of 25 years, provided that the conditions laid down in the product datasheet for the packaging/ transport/ storage/ installation/ use/ repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.
- 6) Type Z₂: Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.
- 7) Mutual distances between services and minimum support distances are given in Annex C.
- 8) If the solution is in combination with the Mulcol® Multiwrap, a maximum of 5 mm protrusion from the surface of the separating element or penetration seal is allowed.

9) Insulation types

The following acoustic insulation types are allowed (or equal):

- ABSound Sonocool
- Jacomassa / Sonimass
- Merfisol Silver Alu
- ThermaCompact TF

The following elastomeric insulation types are given in Annex A and B (or equal, not limited by brand or type):

- Reaction to fire class ≤ B-s1, d0 – e.g. ArmaFlex Ultima, Kaiflex KK Plus S1
- Reaction to fire class ≤ B-s2, d0 – e.g. ArmaFlex AF EVO, Kaiflex KK Plus S2 / ST, K-Flex ST
- Reaction to fire class ≤ B-s3, d0 – e.g. ArmaFlex AF / XG / SH, K-Flex H
- Reaction to fire class ≤ C-s2, d0 – e.g. Kaiflex HT S2
- Reaction to fire class ≤ D-s3, d0 – e.g. ArmaFlex NH / SH / HT

The insulations may also have a B_L, C_L or D_L classification (linear insulation).

10) Pipes types

The following multi layered pipes (or equal) are allowed:

- Alpex DUO, Valsir Pexal, Valsir Mixal and APE Plain (PE-Xb/AL/PE-Xb)
- Uponor and Geberit Mepla (PE-RT/AL/PE-RT)
- Uponor and Henco (PE-Xc/AL/PE-Xc)
- Uponor and REHAU (PE-Xa) and REHAU (PE-Xc)
- SP Superpipe and POLYGON PEX (PE-X/AL/PE-X)
- Valsir Pexal and Valsir Mixal (PE/AL/PE-Xb)
- Wavin Tigris, Protecta-Line System and Alpex F50 Profi (PE-X/AL/PE)

The following fibre composite pipes (or equal) are allowed:

- Aquatechnik Fusio PP-R 80, Aquatechnik Fusio PP-RCT
- Aquatherm Blue-MF, Aquatherm Blue-S, Aquatherm Red-MF, Aquatherm Green-MF, Aquatherm Green-MS, Aquatherm Green-S, Aquatherm Lilac-S, Aquatherm Grey-MS and Aquatherm Orange M
- Bänninger PP-R, Bänninger Climatec PP-RCT and Bänninger Watertec PP-RCT

The following low-noise (silent) pipes (or equal) are allowed:

- Coes PhoNoFire and Coestilen BluePower
- Geberit Silent PP and Geberit Silent dB 20
- Girpi Friaphon and Marley Silent
- Pipelife Master 3 and PhonEX AS
- Poloplast POLO-KAL NG and Poloplast POLO-KAL 3S
- Skolan dB
- Raupiano Plus
- Valsir Triplus, Wavin SiTech+ and Wavin AS
- DykaSono
- Uponor Decibel

3. Performance of the product and references to the methods used for its assessment

Product-type: Mortar		Intended use: Penetration Seal
Assesment method	Essential characteristic	Product Performance
<u>BWR 2 Safety in case of fire</u>		
EN 13501-1	Reaction to fire	A1
EN 13501-2	Resistance to fire	Annex A, B & C
<u>BWR 3 Hygiene, health and enviroment</u>		
EN 1026	Air permeability	No performance determined
EAD 350454-00-1104, Annex C	Water permeability	No performance determined
Declaration of manufacturer & EN 16516	Release of dangerous substances	IA1, S/W 1 - Declaration of manufacturer
<u>BWR 4 Safety in use</u>		
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined
EOTA TR 001:2003	Resistance to impact/movement	No performance determined
EOTA TR 001:2003	Adhesion	No performance determined
EAD 350454-00-1104, Clause 2.2.9	Durability	Z ₂
<u>BWR 5 Protection against noise</u>		
EN 10140-1,2,4,5 / EN ISO 7171-1	Airborne sound insulation	R _w (C;C _{tr}) = 37 (-4;-10) dB
<u>BWR 6 Energy economy and heat retention</u>		
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456	Thermal properties	No performance determined
EN ISO 12572, EN 12086, EN ISO 10456	Water vapour permeability	No performance determined

4. Assessment and Verification of Constancy of Performance (hereinafter AVCP) applied, with reference to its legal base

According to the decision 1999/454/EC – Commission Decision of date 22nd June 1999 on the procedure for attesting the conformity of construction products pursuant to Article 20(2) of Council Directive 89/106/EEC as regards to fire stopping, fire sealing and fire protective products, published in the Official Journal of the European Union (OJEU) L178/52 of 14/07/1999, see <http://eur-lex.europa.eu/JOLIndex.do> of the European Commission1, as amended, the system(s) of assessment and verification of constancy of performance (see Annex V to Regulation (EU) No 305/2011) given in the following table(s) applies (apply).

Product(s)	Intended use(s)	Level(s) or class(es)	System(s)
Fire stopping and Fire Sealing Products	For fire compartmentation and/or fire protection or fire performance	Any	1

5. Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Tasks of the manufacturer:

Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall ensure that the product is in conformity with this European Technical Assessment.

The manufacturer may only use initial / raw / constituent materials stated in the technical documentation of this European Technical Assessment.

The factory production control shall be in accordance with the Control Plan of 7th February 2023 relating to the European Technical Assessment ETA 23/0057 issued on 13/10/2023 which is part of the technical documentation of this European Technical Assessment. The “Control Plan” is laid down in the context of the factory production control system operated by the manufacturer and deposited at UL International (Netherlands) B.V.

The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan.

Other tasks of the manufacturer:

Additional information

The manufacturer shall provide a technical data sheet and an installation instruction with the following minimum information:

(a) Technical data sheet:

- Field of application:
- Building elements for which the penetration seal is suitable, type and properties of the building elements like minimum thickness, density, and - in case of lightweight constructions - the construction requirements.
- Limits in size, minimum thickness etc. of the penetration seal
- Construction of the penetration seal including the necessary components and additional products (e.g. backfilling material) with clear indication whether they are generic or specific.
- Services which the penetration seal is suitable, type and properties of the services like material, diameter, thickness etc. in case of pipes including insulation materials; necessary/allowed supports/fixings (e.g. pipe trays)

(b) Installation instruction:

- Steps to be followed
- Procedure in case of retrofitting
- Stipulations on maintenance, repair and replacement

6. Issued on:

13 October 2023

Report by:



C. Johnson

Senior Staff Engineer

Built Environment

Verified by:



D. Yates

Staff Engineer

Built Environment

Validated by:



Erik Teubler

Head of TAB

Built Environment

For and on behalf of UL International (Netherlands) B.V.

Annex - Resistance to Fire Classification - Mulcol® Multimortar

Annex A.1 - Flexible and rigid walls

A.1.1	Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits	13
A.1.1.1	Cables, trays and conduits	13
A.1.1.2	Cables and trays - Multitherm Bandage	14
A.1.1.3	Single PVC conduits - Multidisc	15
A.1.1.4	Single cables - Multidisc	16
A.1.1.5	Multiple cables - Multidisc	17
A.1.1.6	Plastic pipes with cables - Multiwrap	18
A.1.1.7	Flexible hoses with cables - Multicollar Slim	19
A.1.2	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Cables, trays and conduits	20
A.1.2.1	Cables, trays and conduits	20
A.1.2.2	Cables and trays - Multitherm Bandage	21
A.1.2.3	Single PVC conduits - Multidisc	22
A.1.2.4	Single cables - Multidisc	23
A.1.2.5	Multiple cables - Multidisc	24
A.1.2.6	Plastic pipes with cables - Multiwrap	25
A.1.2.7	Flexible hoses with cables - Multicollar Slim	26
A.1.3	Multimortar - ≥ 100 mm - Cables, trays and conduits	27
A.1.3.1	Cables, trays and conduits	27
A.1.3.2	Cables and trays - Multitherm Bandage	28
A.1.3.3	Single PVC conduits - Multidisc	29
A.1.3.4	Single cables - Multidisc	30
A.1.3.5	Multiple cables - Multidisc	31
A.1.3.6	Plastic pipes with cables - Multiwrap	32
A.1.3.7	Flexible hoses with cables - Multicollar Slim	33
A.1.4	Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes	34
A.1.4.1	Plastic pipes	34
A.1.4.2	Plastic pipes - Multicollar Slim	35
A.1.4.3	Plastic pipes at 45° - Multicollar Slim	36
A.1.4.4	Plastic pipes - Multiwrap	37
A.1.4.5	PP-R multilayer pipes - Multicollar Slim	38
A.1.4.6	Beverage dispense tubing - Multicollar Slim	39
A.1.4.7	Rectangular duct - Multicollar Slim	40
A.1.5	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Combustible pipes	41
A.1.5.1	Plastic pipes - Multicollar Slim	41
A.1.5.2	Plastic pipes at 45° - Multicollar Slim	42
A.1.5.3	Plastic pipes - Multiwrap	43
A.1.5.4	PP-R multilayer pipes - Multicollar Slim	44
A.1.5.5	Beverage dispense tubing - Multicollar Slim	45
A.1.5.6	Rectangular duct - Multicollar Slim	46
A.1.6	Multimortar - ≥ 100 mm - Combustible pipes	47
A.1.6.1	Plastic pipes	47
A.1.6.2	Plastic pipes - Multicollar Slim	48
A.1.6.3	Plastic pipes at 45° - Multicollar Slim	49
A.1.6.4	Plastic pipes - Multiwrap	50
A.1.6.5	PP-R multilayer pipes - Multicollar Slim	51
A.1.6.6	Beverage dispense tubing - Multicollar Slim	52
A.1.6.7	Rectangular duct - Multicollar Slim	53
A.1.7	Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)	54
A.1.7.1	Multilayer pipes (MLC) - Multicollar Slim	54
A.1.7.2	Multilayer pipes (MLC) - Multicollar Slim double	55
A.1.7.3	Multilayer pipes (MLC) - Phenolic foam - Multicollar Slim	56
A.1.7.4	Multilayer pipes (MLC) - Multidisc	57
A.1.8	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Multilayer pipes (MLC)	58
A.1.8.1	Multilayer pipes (MLC) - Multicollar Slim	58
A.1.8.2	Multilayer pipes (MLC) - Multicollar Slim double	59
A.1.8.3	Multilayer pipes (MLC) - Phenolic foam - Multicollar Slim	60
A.1.8.4	Multilayer pipes (MLC) - Multidisc	61
A.1.9	Multimortar - ≥ 100 mm - Multilayer pipes (MLC)	62
A.1.9.1	Multilayer pipes (MLC) - Multicollar Slim	62
A.1.9.2	Multilayer pipes (MLC) - Multicollar Slim double	63
A.1.9.3	Multilayer pipes (MLC) - Phenolic foam - Multicollar Slim	64
A.1.9.4	Multilayer pipes (MLC) - Multidisc	65
A.1.10	Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated mineral wool	66
A.1.10.1	Copper and steel pipes - Stone wool LS 400 / CS	66
A.1.10.2	Copper and steel pipes - Stone wool LI 400 / CI	67

A.1.11	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Metal pipes insulated mineral wool	68
A.1.11.1	Copper and steel pipes - Stone wool LS 400 / CS	68
A.1.11.2	Copper and steel pipes - Stone wool LI 400 / CI	69
A.1.12	Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool	70
A.1.12.1	Copper and steel pipes - Stone wool LS 400 / CS	70
A.1.12.2	Copper and steel pipes - Stone wool LI 400 / CI	71
A.1.12.3	Steel pipes - Glass wool LS 400 / CS - Multicollar <i>Slim</i>	72
A.1.13	Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer	73
A.1.13.1	Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap	73
A.1.13.2	Copper and steel pipes - ArmaFlex Protect LS 400 / CS	75
A.1.14	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Metal pipes insulated elastomer	76
A.1.14.1	Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap	76
A.1.14.2	Copper and steel pipes - ArmaFlex Protect LS 400 / CS	78
A.1.15	Multimortar - ≥ 100 mm - Metal pipes insulated elastomer	79
A.1.15.1	Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap	79
A.1.15.2	Copper and steel pipes - ArmaFlex Protect LS 400 / CS	81
A.1.16	Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes uninsulated	82
A.1.16.1	Copper and steel pipes - Multitherm Bandage	82
A.1.17	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Metal pipes uninsulated	83
A.1.17.1	Copper and steel pipes - Multitherm Bandage	83
A.1.18	Multimortar - ≥ 100 mm - Metal pipes uninsulated	84
A.1.18.1	Copper and steel pipes - Multimastic SP	84
A.1.18.2	Copper and steel pipes - Multisealant GR	85
A.1.18.3	Copper and steel pipes - Multidisc	86
A.1.18.4	Copper and steel pipes - Multitherm Bandage	87
A.1.19	Multimortar + Multimastic FB - ≥ 100 mm - Busbars	88
A.1.19.1	Single busbar - LI 300	88
A.1.19.2	Single busbar - LI 400	90
A.1.19.3	Multiple busbars - LI 300	92
A.1.19.4	Multiple busbars - LI 400	94
A.1.20	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Busbars	96
A.1.20.1	Single busbar - LI 300	96
A.1.20.2	Single busbar - LI 400	98
A.1.20.3	Multiple busbars - LI 300	100
A.1.20.4	Multiple busbars - LI 400	102
A.1.21	Multimortar - ≥ 100 mm - Busbars	104
A.1.21.1	Single busbar - LI 300	104
A.1.21.2	Single busbar - LI 400	106
A.1.21.3	Multiple busbars - LI 300	108
A.1.21.4	Multiple busbars - LI 400	110
A.1.22	Multimortar + Multimastic FB - ≥ 100 mm - Multiple services	112
A.1.22.1	Airconditioning set - Multicollar <i>Slim</i>	112
A.1.22.2	Multiple plastic pipes - Multicollar <i>Slim</i> double	113
A.1.22.3	Multiple Multilayer pipes (MLC) - Multicollar <i>Slim</i>	114
A.1.23	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Multiple services	115
A.1.23.1	Airconditioning set - Multicollar <i>Slim</i>	115
A.1.23.2	Multiple plastic pipes - Multicollar <i>Slim</i> double	116
A.1.23.3	Multiple Multilayer pipes (MLC) - Multicollar <i>Slim</i>	117
A.1.24	Multimortar - ≥ 100 mm - Multiple services	118
A.1.24.1	Airconditioning set - Multicollar <i>Slim</i>	118
A.1.24.2	Multiple plastic pipes - Multicollar <i>Slim</i> double	119
A.1.24.3	Multiple Multilayer pipes (MLC) - Multicollar <i>Slim</i>	120
A.1.25	Multimortar + Multimastic FB - ≥ 100 mm - Gas pipes	121
A.1.25.1	Multiple Corrugated Stainless Steel Tube (CSST) gas pipes - Multitherm Bandage	121
A.1.26	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Gas pipes	122
A.1.26.1	Multiple Corrugated Stainless Steel Tube (CSST) gas pipes - Multitherm Bandage	122
A.1.27	Multimortar ≥ 100 mm - Gas pipes	123
A.1.27.1	Multiple Corrugated Stainless Steel Tube (CSST) gas pipes - Multitherm Bandage	123
A.1.28	Multimortar + Multimastic FB - ≥ 100 mm - Ducting	124
A.1.28.1	Rectangular duct - Multicollar <i>Slim</i>	124
A.1.29	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Ducting	125
A.1.29.1	Rectangular duct - Multicollar <i>Slim</i>	125
A.1.30	Multimortar - ≥ 100 mm - Ducting	126
A.1.30.1	Rectangular duct - Multicollar <i>Slim</i>	126

Annex B.1 - Rigid floors	
B.1.1 Multimortar - ≥ 100 mm - Cables, trays and conduits	127
B.1.1.1 Cables, trays and conduits	127
B.1.1.2 Plastic pipes with cables - Multiwrap	128
B.1.2 Multimortar - ≥ 150 mm - Cables, trays and conduits	129
B.1.2.1 Cables, trays and conduits	129
B.1.2.2 Plastic pipes with cables - Multiwrap	130
B.1.3 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits	131
B.1.3.1 Cables, trays and conduits - Multimastic FB	131
B.1.3.2 Cables, trays and conduits - Multitherm Bandage - Bottom of floor	132
B.1.3.3 Cables, trays and conduits - Multitherm Bandage - Top of floor	133
B.1.4 Multimortar + Multimastic FB - ≥ 150 mm - Cables, trays and conduits	134
B.1.4.1 Cables, trays and conduits - Multimastic FB	134
B.1.4.2 Cables, trays and conduits - Multitherm Bandage - Bottom of floor	135
B.1.4.3 Cables, trays and conduits - Multitherm Bandage - Top of floor	136
B.1.4.4 Single PVC conduits - Multidisc	137
B.1.4.5 Single cables - Multidisc	138
B.1.4.6 Multiple cables - Multidisc	139
B.1.5 Multimortar - ≥ 100 mm - Combustible pipes	140
B.1.5.1 Plastic pipes	140
B.1.5.2 Plastic pipes - Multicollar <i>Slim</i>	141
B.1.5.3 Plastic pipes - Multiwrap	142
B.1.5.4 Plastic pipes (Silent) - Multicollar <i>Slim</i>	144
B.1.5.5 Plastic pipes (Silent) - Multiwrap	145
B.1.5.5 Plastic pipes (Silent) - Multiwrap	146
B.1.5.6 PP-R multiplayer pipes - Multicollar <i>Slim</i>	147
B.1.6 Multimortar - ≥ 150 mm - Combustible pipes	148
B.1.6.1 Plastic pipes	148
B.1.6.2 Plastic pipes - Multicollar <i>Slim</i>	149
B.1.6.3 Plastic pipes with elbow and U-shape collar - Multicollar <i>Slim</i>	150
B.1.6.4 Plastic pipes - Multiwrap	151
B.1.6.5 Plastic pipes (Silent) - Multicollar <i>Slim</i>	153
B.1.6.6 Plastic pipes (Silent) - Multiwrap	154
B.1.6.7 PP-R multiplayer pipes - Multicollar <i>Slim</i>	156
B.1.6.8 Beverage dispense tubing - Multicollar <i>Slim</i>	157
B.1.7 Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes	158
B.1.7.1 Plastic pipes	158
B.1.7.2 Plastic pipes - Multicollar <i>Slim</i>	159
B.1.7.3 Plastic pipes - Multiwrap	160
B.1.7.4 Plastic pipes (Silent) - Multicollar <i>Slim</i>	161
B.1.7.5 Plastic pipes (Silent) - Multiwrap	162
B.1.7.6 PP-R multiplayer pipes - Multicollar <i>Slim</i>	163
B.1.8 Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes	164
B.1.8.1 Plastic pipes	164
B.1.8.2 Plastic pipes - Multicollar <i>Slim</i>	165
B.1.8.3 Plastic pipes - Multiwrap	166
B.1.8.4 Plastic pipes - Multimastic SP	167
B.1.8.5 Plastic pipes - Multisealant GR	168
B.1.8.6 Plastic pipes (Silent) - Multicollar <i>Slim</i>	169
B.1.8.7 Plastic pipes (Silent) - Multiwrap	170
B.1.8.8 PP-R multiplayer pipes - Multicollar <i>Slim</i>	171
B.1.8.9 Beverage dispense tubing - Multicollar <i>Slim</i>	172
B.1.9 Multimortar - ≥ 100 mm - Multilayer pipes (MLC)	173
B.1.9.1 Multilayer pipes (MLC)	173
B.1.10 Multimortar - ≥ 150 mm - Multilayer pipes (MLC)	174
B.1.10.1 Multilayer pipes (MLC)	174
B.1.10.2 Multilayer pipes (MLC) - Multidisc	175
B.1.10.3 Multilayer pipes (MLC) - ArmaFlex Protect LS 400 / CS	176
B.1.11 Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)	177
B.1.11.1 Multilayer pipes (MLC) - Multisealant GR	177
B.1.11.2 Multilayer pipes (MLC) - Elastomer LS 400 / CS - Multisealant GR	178
B.1.11.3 Multilayer pipes (MLC) - PE foam - Multisealant GR	179
B.1.11.4 Multilayer pipes (MLC) - ArmaFlex Protect LS 400 / CS	180
B.1.12 Multimortar + Multimastic FB - ≥ 150 mm - Multilayer pipes (MLC)	181
B.1.12.1 Multilayer pipes (MLC) - Multisealant GR	181
B.1.12.2 Multilayer pipes (MLC) - Multidisc	182
B.1.12.3 Multilayer pipes (MLC) - Stone wool LS 400 / CS	183
B.1.12.4 Multilayer pipes (MLC) - Elastomer LS 400 / CS - Multisealant GR	184
B.1.12.5 Multilayer pipes (MLC) - PE foam - Multisealant GR	185
B.1.12.6 Multilayer pipes (MLC) - ArmaFlex Protect LS 400 / CS	186
B.1.13 Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool	187
B.1.13.1 Copper and steel pipes - Stone wool LS 400 / CS	187
B.1.13.2 Copper and steel pipes - Stone wool LI 400 / CI	188
B.1.13.3 Copper and steel pipes - Glass wool LS 400 / CS	189

B.1.14	Multimortar - ≥ 150 mm - Metal pipes insulated mineral wool	190
B.1.14.1	Copper and steel pipes - Stone wool LS 400 / CS	190
B.1.14.2	Copper and steel pipes - Stone wool LI 400 / CI	191
B.1.14.3	Copper and steel pipes - Glass wool LI 400 / CI	192
B.1.15	Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated mineral wool	193
B.1.15.1	Copper and steel pipes - Stone wool LS 400 / CS	193
B.1.15.2	Copper and steel pipes - Stone wool LI 400 / CI	194
B.1.15.3	Copper and steel pipes - Glass wool LI 400 / CI	195
B.1.16	Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated mineral wool	196
B.1.16.1	Copper and steel pipes - Stone wool LS 400 / CS	196
B.1.16.2	Copper and steel pipes - Stone wool LI 400 / CI	197
B.1.16.3	Copper and steel pipes - Glass wool LI 400 / CI	198
B.1.17	Multimortar - ≥ 100 mm - Metal pipes insulated elastomer	199
B.1.17.1	Copper and steel pipes - Elastomer LI 300 / CI - Multicollar <i>Slim</i>	199
B.1.17.2	Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap	200
B.1.17.3	Copper and steel pipes - ArmaFlex Protect LS 400 / CS	202
B.1.18	Multimortar - ≥ 150 mm - Metal pipes insulated elastomer	203
B.1.18.1	Copper and steel pipes - Elastomer LI 300 / CI - Multicollar <i>Slim</i>	203
B.1.18.2	Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap	204
B.1.18.3	Copper and steel pipes - ArmaFlex Protect LS 400 / CS	206
B.1.19	Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer	207
B.1.19.1	Copper and steel pipes - Elastomer LI 300 / CI - Multicollar <i>Slim</i>	207
B.1.19.2	Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap	208
B.1.19.3	Copper and steel pipes - Elastomer LS 400 / CS - Multisealant GR	209
B.1.19.4	Copper and steel pipes - ArmaFlex Protect LS 400 / CS	211
B.1.20	Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated elastomer	212
B.1.20.1	Copper and steel pipes - Elastomer LI 300 / CI - Multicollar <i>Slim</i>	212
B.1.20.2	Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap	213
B.1.20.3	Copper and steel pipes - Elastomer LS 400 / CS - Multisealant GR	214
B.1.20.4	Copper and steel pipes - ArmaFlex Protect LS 400 / CS	216
B.1.21	Multimortar - ≥ 100 mm - Metal pipes uninsulated	217
B.1.21.1	Copper and steel pipes - Multimastic SP	217
B.1.21.2	Copper and steel pipes - Multisealant GR	218
B.1.21.3	Copper and steel pipes - Multidisc	219
B.1.22	Multimortar - ≥ 150 mm - Metal pipes uninsulated	220
B.1.22.1	Copper and steel pipes - Multimastic SP	220
B.1.22.2	Copper and steel pipes - Multimastic SP - either side	221
B.1.22.3	Copper and steel pipes - Multisealant GR	222
B.1.22.4	Copper and steel pipes - Multidisc	223
B.1.22.5	Copper and steel pipes - Multitherm Bandage - either side	224
B.1.23	Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes uninsulated	225
B.1.23.1	Copper and steel pipes - Multimastic SP	225
B.1.23.2	Copper and steel pipes - Multisealant GR	226
B.1.23.3	Copper and steel pipes - Multidisc	227
B.1.24	Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes uninsulated	228
B.1.24.1	Copper and steel pipes - Multimastic SP	228
B.1.24.2	Copper and steel pipes - Multisealant GR	229
B.1.24.3	Copper and steel pipes - Multidisc	230
B.1.24.4	Copper and steel pipes - Multitherm Bandage	231
B.1.25	Multimortar - ≥ 100 mm - Busbars	232
B.1.25.1	Single busbar	232
B.1.25.2	Multiple busbars	234
B.1.26	Multimortar - ≥ 150 mm - Busbars	236
B.1.26.1	Single busbar	236
B.1.26.2	Multiple busbars	238
B.1.27	Multimortar + Multimastic FB - ≥ 100 mm - Busbars	240
B.1.27.1	Single busbar	240
B.1.27.2	Multiple busbars	242
B.1.28	Multimortar + Multimastic FB - ≥ 150 mm - Busbars	244
B.1.28.1	Single busbar	244
B.1.28.2	Multiple busbars	246
B.1.29	Multimortar + Multimastic FB - ≥ 150 mm - Gas pipes	248
B.1.29.1	Corrugated stainless steel tube gas (CSST) pipes - Multicollar <i>Slim</i> - Multitherm Bandage	248
B.1.29.2	Corrugated stainless steel tube gas (CSST) pipes - Multicollar <i>Slim</i> - Multitherm Bandage	249
B.1.30	Multimortar - ≥ 150 mm - Gas pipes	250
B.1.30.1	Corrugated stainless steel tube gas (CSST) pipes - Multicollar <i>Slim</i> - Multitherm Bandage	250
B.1.30.2	Corrugated stainless steel tube gas (CSST) pipes - Multicollar <i>Slim</i> - Multitherm Bandage	251



B.1.31	Multimortar - ≥ 150 mm - Electrical room services	252
B.1.31.1	Cables - Multifoam 2K	252
B.1.31.2	Cables - Multisealant GR	253
B.1.31.3	Multiple cables - Multifoam 2K	254
B.1.31.4	Multiple cables - Multisealant GR	255
B.1.31.5	Flexible conduit with cables - Multifoam 2K	256
B.1.31.6	Flexible conduit with cables - Multisealant GR	257
B.1.31.7	Multilayer pipes (MLC) - Multifoam 2K	258
B.1.31.8	Multilayer pipes (MLC) - PE foam insulation LS 50 / CS - Multisealant GR	259
B.1.31.9	Multilayer pipes (MLC) - Multisealant GR - Multitherm Bandage	260
B.1.31.10	Copper and steel pipes - Multifoam 2K - Multitherm Bandage	261
B.1.31.11	Copper and steel pipes - Multisealant GR - Multitherm Bandage	262

Annex C - General

C.1	Flexible and rigid wall - General	263
C.1.2	Flexible and rigid wall - Maximum seal dimensions	264
C.1.2.1	Multimortar - ≥ 100 mm	264
C.1.2.2	Multimortar + Multimastic FB system - ≥ 100 mm	265
C.1.2.3	Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm	266
C.2	Rigid floor - General	267
C.2.1	Mutual distances & distance to first support	267
C.2.2	Rigid floor - General - Maximum seal dimensions	268
C.2.2.1	Multimortar - ≥ 100 mm	268
C.2.2.2	Multimortar + Multimastic FB system - ≥ 100 mm	269
C.2.2.3	Multimortar + Multimastic FB system - ≥ 150 mm	270

A.1.1 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

A.1.1.1 Cables, trays and conduits





Drawing: FW.E-CT-4-MM2.5.10

Services	Classification
Metal cable ladders	EI 60, E 90
Metal (non-)perforated cable trays	EI 90, E 120
Steel wire mesh cable trays (baskets)	EI 60, E 90
Cables ≤ Ø 80 mm (single or bundled)	EI 60, E 90
Cables ≤ Ø 21 mm in a tied bundle ≤ Ø 100 mm	EI 60, E 120
Plastic conduits ≤ Ø 16 mm	EI 60 U/C, E 90 U/C
Copper conduits ≤ Ø 16 mm	EI 30 C/U, E 120 C/U
Steel conduits ≤ Ø 16 mm	EI 120 C/U

A.1.1 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits



A.1.1.2 Cables and trays - Multitherm Bandage



Services	Insulation (mm)	Classification
Metal (non-)perforated cable trays	LI 150 - Multitherm Bandage either side	EI 120
Steel wire mesh cable trays (baskets)		
Cables $\leq \varnothing 21$ mm		

A.1.1 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

A.1.1.3 Single PVC conduits - Multidisc





Drawing: FW.E-EP-M2-MM2.5.10

Services	Product	Allowed cables	Classification
Plastic conduits $\leq \varnothing 19$ mm with or without cables	Multidisc	UTP / F-UTP / F-STP / YMVK	EI 120 U/U
Plastic conduits $\leq \varnothing 25$ mm with or without cables			EI 90 U/U, E 120 U/U

A.1.1 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

A.1.1.4 Single cables - Multidisc





Drawing: FW.E-EC-M2-MM2.5.10

Services	Product	Classification
Single electrical cables $\leq \varnothing 21 \text{ mm}$, YMVK 5 x 2.5 mm ²	Multidisc	EI 60, E 90

A.1.1 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

A.1.1.5 Multiple cables - Multidisc





Drawing: FW.E-ECB-MM2.5.10

Services	Product	Classification
Telecommunication cables, max. 15 pcs., max. $\leq \varnothing$ 25 mm	Multidisc	EI 60, E 120

A.1.1 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

A.1.1.6 Plastic pipes with cables - Multiwrap

Front view





Drawing: FW.E-PPEC-MW2-MM2.5.10

Services	Pipe dimensions (mm)		Product	Allowed Cables	Classification
	Outer dimension	Wall thickness			
PE(-HD) / PE-X / ABS / SAN+PVC	$\leq \varnothing 110$	2.7 - 10	Multiwrap (2 layers)	Sheathed cables $\leq \varnothing 80$ mm (single or bundled) Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	EI 90 U/C, E 120 U/C
PP					
PVC(-U/-C)					

A.1.1 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

A.1.1.7 Flexible hoses with cables - Multicollar Slim





Services	Number of sleeves	Product	Allowed cables	Classification
Ribbed PE-sleeve conduit $\leq \varnothing 63$ mm, with or without cables	≤ 4	Multicollar Slim	Sheathed cables $\leq \varnothing 21$ mm (single or bundled) Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	EI 90 U/C, E 120 U/C

A.1.2 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -

Cables, trays and conduits

A.1.2.1 Cables, trays and conduits

Front view



Drawing: FW.E-CT-4-MM3.4.10



Services	Classification
Metal cable ladders	EI 90, E 120
Metal (non-)perforated cable trays	EI 120
Steel wire mesh cable trays (baskets)	EI 120
Cables $\leq \varnothing 80 \text{ mm}$ (single or bundled)	EI 90, E 120
Cables $\leq \varnothing 21 \text{ mm}$ in a tied bundle $\leq \varnothing 100 \text{ mm}$	EI 60, E 120
Non sheathed cables $\leq \varnothing 24 \text{ mm}$	EI 60, E 120
Plastic conduits $\leq \varnothing 16 \text{ mm}$	EI 120 U/C
Copper conduits $\leq \varnothing 16 \text{ mm}$	EI 45 C/U, E 90 C/U
Steel conduits $\leq \varnothing 16 \text{ mm}$	EI 90 C/U

A.1.2 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -

Cables, trays and conduits



A.1.2.2 Cables and trays - Multitherm Bandage

Front view



Drawing: FW.E-CT-MM3.4.10-B1.1.10

Services	Insulation (mm)	Classification
Metal (non-)perforated cable trays		
Steel wire mesh cable trays (baskets)	LI 150 - Multitherm Bandage either side	EI 120
Cables ≤ Ø 21 mm		



A.1.2**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Cables, trays and conduits****A.1.2.3****Single PVC conduits - Multidisc**Front view

Drawing: FW.E-EP-M2-MM3.4.10

Services	Product	Allowed cables	Classification
Plastic conduits ≤ Ø 19 mm with or without cables	Multidisc	UTP / F-UTP / F-STP / YMVK	EI 120 U/U
Plastic conduits ≤ Ø 25 mm with or without cables			EI 90 U/U, E 120 U/U

A.1.2



**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Cables, trays and conduits
Single cables - Multidisc**

A.1.2.4

Drawing: FW.E-EC-M2-MM3.4.10

Services	Product	Classification
Single electrical cables ≤ Ø 21 mm, YMVK 5 x 2.5 mm ²	Multidisc	EI 60, E 90



A.1.2 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Cables, trays and conduits
A.1.2.5 Multiple cables - Multidisc



Drawing: FW.E-ECB-MM3.4.10



Services	Product	Classification
Telecommunication cables, max. 15 pcs., max. $\leq \varnothing 25 \text{ mm}$	Multidisc	EI 60, E 120

A.1.2 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Cables, trays and conduits
A.1.2.6 Plastic pipes with cables - Multiwrap



Services	Pipe dimensions (mm)		Product	Allowed Cables	Classification
	Outer dimension	Wall thickness			
PE(-HD) / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7 - 10	Multiwrap (2 layers)	Sheathed cables ≤ Ø 80 mm (single or bundled) Cables ≤ Ø 21 mm in a tied bundle ≤ Ø 100 mm	EI 90 U/C, E 120 U/C
PP					
PVC(-U/-C)					

A.1.2 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Cables, trays and conduits
A.1.2.7 Flexible hoses with cables - Multicollar Slim



Drawing: FW.E-MC30-ECH4-MM3.4.30


Services	Number of sleeves	Product	Allowed cables	Classification
Ribbed PE-sleeve conduit ≤ Ø 63 mm, with or without cables	≤ 4	Multicollar Slim	Sheathed cables ≤ Ø 21 mm (single or bundled) Cables ≤ Ø 21 mm in a tied bundle ≤ Ø 100 mm	EI 90 U/C, E 120 U/C

A.1.3



Multimortar - ≥ 100 mm - Cables, trays and conduits

A.1.3.1



Cables, trays and conduits



Services	Classification
Metal cable ladders	EI 90, E 120
Metal (non-)perforated cable trays	EI 120
Steel wire mesh cable trays (baskets)	EI 120
Cables $\leq \varnothing 80$ mm (single or bundled)	EI 90, E 120
Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	EI 60, E 120
Non sheathed cables $\leq \varnothing 24$ mm	EI 60, E 120
Plastic conduits $\leq \varnothing 16$ mm	EI 120 U/C
Copper conduits $\leq \varnothing 16$ mm	EI 45 C/U, E 90 C/U
Steel conduits $\leq \varnothing 16$ mm	EI 90 C/U



A.1.3**Multimortar - ≥ 100 mm - Cables, trays and conduits****A.1.3.2****Cables and trays - Multitherm Bandage**

Services	Insulation (mm)	Classification
Metal (non-)perforated cable trays		
Steel wire mesh cable trays (baskets)	LI 150 - Multitherm Bandage either side	EI 120
Cables $\leq \varnothing 21$ mm		

A.1.3**Multimortar - ≥ 100 mm - Cables, trays and conduits****A.1.3.3****Single PVC conduits - Multidisc**



Drawing: FW.E-EP-M2-MM1.2.10

Services	Product	Allowed cables	Classification
Plastic conduits $\leq \varnothing 19$ mm with or without cables	Multidisc	UTP / F-UTP / F-STP / YMVK	EI 120 U/U
Plastic conduits $\leq \varnothing 25$ mm with or without cables			EI 90 U/U, E 120 U/U

A.1.3**Multimortar - ≥ 100 mm - Cables, trays and conduits****A.1.3.4****Single cables - Multidisc**

Drawing: FW.E-EC-M2-MM1.2.10

Services	Product	Classification
Single electrical cables $\leq \varnothing 21$ mm, YMVK 5 x 2.5 mm ²	Multidisc	EI 60, E 90



A.1.3**Multimortar - ≥ 100 mm - Cables, trays and conduits****A.1.3.5****Multiple cables - Multidisc**

Drawing: FW.E-ECB-MM1.2.10



Services	Product	Classification
Telecommunication cables, max. 15 pcs., max. $\leq \varnothing$ 25 mm	Multidisc	EI 60, E 120

A.1.3**Multimortar - ≥ 100 mm - Cables, trays and conduits****A.1.3.6****Plastic pipes with cables - Multiwrap**



Front view



Services	Pipe dimensions (mm)		Product	Allowed Cables	Classification
	Outer dimension	Wall thickness			
PE(-HD) / PE-X / ABS / SAN+PVC	$\leq \varnothing 110$	2.7 - 10	Multiwrap (2 layers)	Sheathed cables $\leq \varnothing 80$ mm (single or bundled) Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	EI 90 U/C, E 120 U/C
PP					
PVC(-U/-C)					

A.1.3**Multimortar - ≥ 100 mm - Cables, trays and conduits****A.1.3.7****Flexible hoses with cables - Multicollar Slim**

Services	Number of sleeves	Product	Allowed cables	Classification
Ribbed PE-sleeve conduit $\leq \varnothing 63$ mm with or without cables	≤ 4	Multicollar Slim	Sheathed cables $\leq \varnothing 21$ mm (single or bundled) Cables $\leq \varnothing 21$ mm in a tied bundle	EI 90 U/C, E 120 U/C

A.1.4**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****A.1.4.1****Plastic pipes**Front view



Drawing: FW.E-PP-MM2.5.10-G2.0.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
PE-HD / PE-X / ABS / SAN+PVC	$\leq \emptyset 32$	3.0	EI 90 U/C

A.1.4

Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes

A.1.4.2

Plastic pipes - Multicollar Slim

Services	Pipe dimensions (mm)		Product	Classification		
	Outer dimension	Wall thickness				
PE(-HD) / PE-X / ABS / SAN+PVC	$\leq \varnothing 110$	2.7 - 6.6	Multicollar Slim	EI 120 U/U		
PP		2.7				
PVC(-U/-C)						



A.1.4

Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes

A.1.4.3



Plastic pipes at 45° - Multicollar Slim

Front view





Drawing: FW.E-PP-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	$\leq \text{Ø} 110$	2.7	Multicollar Slim	EI 60 U/U, E 90 U/U
PP				
PVC(-U/-C)				

A.1.4**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****A.1.4.4****Plastic pipes - Multiwrap**

Drawing: FW.E-PP-MW2-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PP	$\leq \varnothing 110$	10.0	Multiwrap (2 layers)	EI 120 U/C
			Multiwrap (4 layers)	EI 120 U/U

A.1.4**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****A.1.4.5****PP-R multilayer pipes - Multicollar *Slim***

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Aquatherm Green	$\leq \varnothing 50$	6.9	Multicollar <i>Slim</i>	EI 120 U/C



A.1.4

Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes

A.1.4.6



Beverage dispense tubing - Multicollar Slim

Front view



Drawing: FW.E-MC30-DCT52-MM2.5.10



Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Hoses no.	Type	Thickness (mm)	Configuration		
Drinks tubing system	$\leq \varnothing 145$	≤ 52	Elastomeric foam	8 - 35	CS	Multicollar Slim	EI 60 U/C

A.1.4**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****A.1.4.7****Rectangular duct - Multicollar *Slim***

Drawing: FW.E-MC30-AD-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rectangular plastic duct	$\leq 220 \times 90$	1.0	Multicollar <i>Slim</i>	EI 45 U/C
		2.0		EI 120 U/C

A.1.5 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Combustible pipes
A.1.5.1 Plastic pipes - Multicollar Slim





Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7 - 6.6	Multicollar Slim	EI 120 U/U
PP		2.7		
PVC(-U/-C)				

A.1.5 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -

Combustible pipes



A.1.5.2 Plastic pipes at 45° - Multicollar Slim

Front view





Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7	Multicollar Slim	EI 60 U/U, E 90 U/U
PP				
PVC(-U/-C)				

A.1.5 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Combustible pipes
A.1.5.3 Plastic pipes - Multiwrap



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PP	≤ Ø 110	10.0	Multiwrap (2 layers)	EI 120 U/C
			Multiwrap (4 layers)	EI 120 U/U

A.1.5 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Combustible pipes
A.1.5.4 PP-R multilayer pipes - Multicollar Slim





Drawing: FW.E-MLF-MM3.4.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Aquatherm Green	≤ Ø 50	6.9	Multicollar Slim	EI 120 U/C



A.1.5 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Combustible pipes
A.1.5.5 Beverage dispense tubing - Multicollar Slim

Front view





Drawing: FW.E-MC30-DCT52-MM3.4.10

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Hoses no.	Type	Thickness (mm)	Configuration		
Drinks tubing system	≤ Ø 145	≤ 52	Elastomeric foam	8 - 35	CS	Multicollar Slim	EI 60 U/C

A.1.5**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Combustible pipes****A.1.5.6****Rectangular duct - Multicollar *Slim***Front view

Drawing: FW.E-MC30-AD-MM3.4.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rectangular plastic duct	≤ 220 x 90	1.0	Multicollar <i>Slim</i>	EI 45 U/C
		2.0		EI 120 U/C



A.1.6**Multimortar - ≥ 100 mm - Combustible pipes****A.1.6.1****Plastic pipes**Front view

Drawing: FW.E-PP-MM3.4.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 32$	2.0 - 3.0	
PP		4.4	EI 180 U/C



A.1.6**Multimortar - ≥ 100 mm - Combustible pipes****A.1.6.2****Plastic pipes - Multicollar Slim**

Front view



Drawing: FW.E-MC30-PP-MM1.2.10



Services	Pipe dimensions (mm)		Product	Classification		
	Outer dimension	Wall thickness				
PE(-HD) / PE-X / ABS / SAN+PVC	$\leq \text{Ø} 110$	2.7 - 6.6	Multicollar Slim	EI 120 U/U		
PP		2.7				
PVC(-U/-C)						

A.1.6**Multimortar - ≥ 100 mm - Combustible pipes****A.1.6.3****Plastic pipes at 45° - Multicollar Slim**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	$\leq \text{Ø} 110$	2.7	Multicollar Slim	EI 60 U/U, E 90 U/U
PP				
PVC(-U/-C)				



A.1.6**Multimortar - ≥ 100 mm - Combustible pipes****A.1.6.4****Plastic pipes - Multiwrap**

Front view





Drawing: FW.E-PP-MW2-MM1.2.10-T



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PP	$\leq \varnothing 110$	10.0	Multiwrap (2 layers)	EI 120 U/C
			Multiwrap (4 layers)	EI 120 U/U

A.1.6**Multimortar - ≥ 100 mm - Combustible pipes****A.1.6.5****PP-R multilayer pipes - Multicollar Slim**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Aquatherm Green	$\leq \varnothing 50$	6.9	Multicollar Slim	EI 120 U/C



A.1.6**Multimortar - ≥ 100 mm - Combustible pipes****A.1.6.6****Beverage dispense tubing - Multicollar Slim**

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Hoses no.	Type	Thickness (mm)	Configuration		
Drinks tubing system	$\leq \varnothing 47$ $\leq \varnothing 145$	≤ 3 ≤ 52	Elastomeric foam	8 - 35	CS	Multicollar Slim	EI 60 U/C



A.1.6**Multimortar - ≥ 100 mm - Combustible pipes****A.1.6.7****Rectangular duct - Multicollar *Slim***

Drawing: FW.E-MC30-AD-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rectangular plastic duct	$\leq 220 \times 90$	1.0	Multicollar <i>Slim</i>	EI 45 U/C
		2.0		EI 120 U/C

A.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****A.1.7.1****Multilayer pipes (MLC) - Multicollar Slim**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	≤ Ø 32	3.2	Multicollar Slim	EI 45 C/U, E 90 C/U
		3.2 - 4.0		EI 45 U/C, E 90 U/C
	≤ Ø 50	4.0		EI 60 U/C, E 120 U/C



A.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****A.1.7.2****Multilayer pipes (MLC) - Multicollar *Slim* double**

Drawing: FW.E-MLA-MM2.5.10



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	$\leq \varnothing 75$	6.0	Multicollar <i>Slim</i> double	EI 90 U/C, E 120 U/C

A.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****A.1.7.3****Multilayer pipes (MLC) - Phenolic foam - Multicollar Slim**

Front view





Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Multilayer pipes (MLC)	$\leq \varnothing 20$	2.0	Kingspan Kooltherm	15 - 40	LS 400 / CS	Multicollar Slim	EI 60 U/C
	$\leq \varnothing 40$	3.5					
	$\leq \varnothing 63$	4.5		20 - 40			

A.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****A.1.7.4****Multilayer pipes (MLC) - Multidisc**Front view

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	$\leq \varnothing 16$	2.0	Multidisc	EI 60 U/C, E 120 U/C



A.1.8 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Multilayer pipes (MLC)
A.1.8.1 Multilayer pipes (MLC) - Multicollar Slim



Drawing: FW-MLA-MM3.4.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	≤ Ø 32	3.2	Multicollar Slim	EI 45 C/U, E 90 C/U
		3.2 - 4.0		EI 45 U/C, E 90 U/C
	≤ Ø 50	4.0		EI 60 U/C, E 120 U/C

A.1.8 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Multilayer pipes (MLC)
A.1.8.2 Multilayer pipes (MLC) - Multicollar Slim double





Drawing: FW-MLA-MM3.4.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	≤ Ø 75	6.0	Multicollar Slim double	EI 90 U/C, E 120 U/C

A.1.8 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -



Multilayer pipes (MLC)

A.1.8.3 Multilayer pipes (MLC) - Phenolic foam - Multicollar Slim



Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Multilayer pipes (MLC)	≤ Ø 20	2.0	Kingspan Kooltherm	15 - 40	LS 400 / CS	Multicollar Slim	EI 60 U/C
	≤ Ø 40	3.5					
	≤ Ø 63	4.5		20 - 40			



A.1.8 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Multilayer pipes (MLC)
A.1.8.4 Multilayer pipes (MLC) - Multidsc





Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	≤ Ø 16	2.0	Multidisc	EI 60 U/C, E 120 U/C

A.1.9 Multimortar - ≥ 100 mm - Multilayer pipes (MLC)

A.1.9.1 Multilayer pipes (MLC) - Multicollar Slim



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	$\leq \varnothing 32$	3.2	Multicollar Slim	EI 45 C/U, E 90 C/U
		3.2 - 4.0		EI 45 U/C, E 90 U/C
	$\leq \varnothing 50$	4.0		EI 60 U/C, E 120 U/C

A.1.9**Multimortar - ≥ 100 mm - Multilayer pipes (MLC)****A.1.9.2****Multilayer pipes (MLC) - Multicollar Slim double**

Drawing: FW.E-MLA-MM1.2.10



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	$\leq \varnothing 75$	6.0	Multicollar Slim double	EI 90 U/C, E 120 U/C

A.1.9



Multimortar - ≥ 100 mm - Multilayer pipes (MLC)

A.1.9.3

Multilayer pipes (MLC) - Phenolic foam - Multicollar Slim



Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Multilayer pipes (MLC)	$\leq \varnothing 20$	2.0	Kingspan Kooltherm	15 - 40	LS 400 / CS	Multicollar Slim	EI 60 U/C
	$\leq \varnothing 40$	3.5					
	$\leq \varnothing 63$	4.5		20 - 40			



A.1.9**Multimortar - ≥ 100 mm - Multilayer pipes (MLC)****A.1.9.4****Multilayer pipes (MLC) - Multidisc**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	$\leq \varnothing 16$	2.0	Multidisc	EI 60 U/C, E 120 U/C

A.1.10 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated mineral wool

A.1.10.1 Copper and steel pipes - Stone wool LS 400 / CS

Front view





Drawing: FW.E-CU-MM2.5.20

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless-) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool $\geq 80 \text{ kg/m}^3$	25	LS 400 / CS	EI 90 C/U, E 120 C/U
	$\leq \varnothing 54$	≥ 1.5				
(Stainless) Steel / cast iron	$\leq \varnothing 12$	≥ 1.5	Stone wool $\geq 80 \text{ kg/m}^3$	30	CS	EI 60 C/U EI 60 C/U, E 120 C/U EI 90 C/U, E 120 C/U
	$\leq \varnothing 114.3$	≥ 3.6				
	$\leq \varnothing 219.1$	≥ 4.0				
	$\leq \varnothing 324$	≥ 3.7				

A.1.10 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated mineral wool

A.1.10.2 Copper and steel pipes - Stone wool LI 400 / CI





Drawing: FW.E-CU-MM2.5.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless-) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m ³)	≥ 25	LI 400 / CI	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5				EI 90 C/U, E 120 C/U
(Stainless) Steel / cast iron	$\leq \varnothing 114.3$	≥ 3.6				EI 120 C/U
	$\leq \varnothing 324$	≥ 3.7				



A.1.11 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Metal pipes insulated mineral wool
A.1.11.1 Copper and steel pipes - Stone wool LS 400 / CS

Front view



Drawing: FW.E-CU-MM3.4.20

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless-) steel / cast iron	≤ Ø 22	≥ 1.0	Stone wool (≥ 80 kg/m³)	25	LS 400 / CS	EI 120 C/U
	≤ Ø 54	≥ 1.5				
(Stainless) Steel / cast iron	≤ Ø 12	≥ 1.5	Stone wool (≥ 80 kg/m³)	30	CS	EI 60 C/U
	≤ Ø 114.3	≥ 3.6				EI 60 C/U, E 120 C/U
	≤ Ø 219.1	≥ 4.0				EI 90 C/U, E 120 C/U
	≤ Ø 324	≥ 3.7				EI 90 C/U, E 120 C/U



A.1.11**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Metal pipes insulated mineral wool****A.1.11.2****Copper and steel pipes - Stone wool LI 400 / CI**Front view

Drawing: FW.E-CU-MM3.4.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless-) steel / cast iron	≤ Ø 22	≥ 1.0	Stone wool (≥ 80 kg/m³)	≥ 25	LI 400 / CI	EI 120 C/U
	≤ Ø 54	≥ 1.5				
(Stainless) Steel / cast iron	≤ Ø 114.3	≥ 3.6				
	≤ Ø 324	≥ 3.7				

A.1.12**Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool****A.1.12.1****Copper and steel pipes - Stone wool LS 400 / CS**

Front view





Drawing: FW.E-CU-MM1.2.20.LS

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless-) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool $\geq 80 \text{ kg/m}^3$	25	LS 400 / CS	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5				
(Stainless) Steel / cast iron	$\leq \varnothing 12$	≥ 1.5	30	CS	EI 60 C/U	EI 60 C/U, E 120 C/U
	$\leq \varnothing 114.3$	≥ 3.6				
	$\leq \varnothing 219.1$	≥ 4.0				
	$\leq \varnothing 324$	≥ 3.7				EI 90 C/U, E 120 C/U

A.1.12



Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool

A.1.12.2

Copper and steel pipes - Stone wool LI 400 / CI

Drawing: FW.E-CU-MM1.2.20



Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless-) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m ³)	≥ 25	LI 400 / CI	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5				
(Stainless) Steel / cast iron	$\leq \varnothing 114.3$	≥ 3.6				
	$\leq \varnothing 324$	≥ 3.7				

A.1.12**Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool****A.1.12.3****Steel pipes - Glass wool LS 400 / CS - Multicollar Slim**

Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
(Stainless) Steel / cast iron	$\leq \varnothing 76.2$	≥ 3.3	Isover	≥ 30	LS 400 / CS	Multicollar Slim	EI 90 C/U, E 120 C/U
	$\leq \varnothing 139.7$	≥ 4.0	Climclover Glass wool ($\geq 33 \text{ kg/m}^3$)	≥ 50			EI 60 C/U, E 90 C/U

A.1.13 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer

A.1.13.1 Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap



Drawing: FW.E-CU-MW2-MM2.5.22

Services	Pipe dimensions (mm)		Insulation			Product	Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
Copper / (stainless) steel / cast iron	≤ Ø 12	≥ 1.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	9	LS 400 / CS	Multiwrap (2 layers)	EI 120 C/U, E 180 C/U	
	≤ Ø 35	≥ 1.1		35			EI 90 C/U, E 120 C/U	
	≤ Ø 54	≥ 1.5		60			EI 120 C/U	
	≤ Ø 114.3	≥ 3.6		38			EI 60 C/U, E 120 C/U	
	≤ Ø 219.1	≥ 4.0		15			EI 60 C/U, E 120 C/U	
	≤ Ø 324	≥ 3.7		32			EI 45 C/U, E 120 C/U	
(Stainless) Steel / cast iron				50	LS 400 / CS	Multiwrap (3 layers)	EI 120 C/U	
				CS			EI 60 C/U, E 120 C/U	
				CS			EI 45 C/U, E 180 C/U	
				CS			EI 90 C/U, E 180 C/U	



A.1.13 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer**A.1.13.1 Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap**

Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	Kaiflex ST (min. class B-s3, d0 B _L -s3, d0)	9 - 32	LS 400 / CS	Multiwrap (2 layers)	EI 90 C/U, E 120 C/U
				32			EI 120 C/U
	≤ Ø 54	≥ 1.5		13 - 32			EI 30 C/U, E 120 C/U
				32			EI 60 C/U, E 120 C/U
	≤ Ø 114.3	≥ 3.6		13			EI 45 C/U, E 120 C/U
				13 - 32			
	≤ Ø 168.3	≥ 4.5		32			EI 60 C/U, E 120 C/U
(Stainless) Steel / cast iron							

A.1.13 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer



A.1.13.2 Copper and steel pipes - ArmaFlex Protect LS 400 / CS

Front view



Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 U/C
	$\leq \varnothing 54$	≥ 1.5		25		EI 90 C/U, E 120 C/U

A.1.14 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Metal pipes insulated elastomer
A.1.14.1 Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap





Drawing: FW.E-CU-MW2-MM3.4.22

Services	Pipe dimensions (mm)		Insulation			Product	Classification		
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration				
Copper / (stainless) steel / cast iron	≤ Ø 12	≥ 1.0	ArmaFlex (min. class B-s3, d0 B _L -s3, d0)	9	LS 400 / CS	Multiwrap (2 layers)	EI 120 C/U, E 180 C/U		
	≤ Ø 35	≥ 1.1		35			EI 90 C/U, E 120 C/U		
	≤ Ø 54	≥ 1.5		60			EI 120 C/U		
	≤ Ø 114.3	≥ 3.6		38			EI 60 C/U, E 120 C/U		
	≤ Ø 219.1	≥ 4.0		15			EI 60 C/U, E 120 C/U		
	≤ Ø 324	≥ 3.7		32			EI 45 C/U, E 120 C/U		
(Stainless) Steel / cast iron			LS 400 / CS	50	CS	Multiwrap (3 layers)	EI 120 C/U		
							EI 60 C/U, E 120 C/U		

- A.1.14** **Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -**
Metal pipes insulated elastomer
- A.1.14.1** **Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap**

Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless-) steel / cast iron	≤ Ø 22	≥ 1.0	Kaiflex ST (min. class B-s3, d0 B _L -s3, d0)	9 - 32	LS 400 / CS	Multiwrap (2 layers)	EI 90 C/U, E 120 C/U
				32			EI 120 C/U
	≤ Ø 54	≥ 1.5		13 - 32			EI 30 C/U, E 120 C/U
				32			EI 60 C/U, E 120 C/U
	≤ Ø 114.3	≥ 3.6		13			EI 45 C/U, E 120 C/U
				13 - 32			
	≤ Ø 168.3	≥ 4.5		32			EI 60 C/U, E 120 C/U

A.1.14**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Metal pipes insulated elastomer****A.1.14.2****Copper and steel pipes - ArmaFlex Protect LS 400 / CS**Front view

Drawing: FW.E-CU-MM3.4.25



Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 U/C
	≤ Ø 54	≥ 1.5		25		EI 90 C/U, E 120 C/U

A.1.15

Multimortar - ≥ 100 mm - Metal pipes insulated elastomer

A.1.15.1

Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap





Drawing: FW.E-CU-MW2-MM1.2.22

Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	$\leq \varnothing 12$	≥ 1.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	9	LS 400 / CS	Multiwrap (2 layers)	EI 120 C/U, E 180 C/U
	$\leq \varnothing 35$	≥ 1.1		35			EI 90 C/U, E 120 C/U
	$\leq \varnothing 54$	≥ 1.5		60			EI 120 C/U
	$\leq \varnothing 114.3$	≥ 3.6		38			EI 60 C/U, E 120 C/U
(Stainless) Steel / cast iron	$\leq \varnothing 219.1$	≥ 4.0	CS	15	CS	Multiwrap (3 layers)	EI 60 C/U, E 120 C/U
	$\leq \varnothing 324$	≥ 3.7		32			EI 45 C/U, E 180 C/U
				50			EI 45 C/U, E 180 C/U
							EI 90 C/U, E 180 C/U

A.1.15**Multimortar - ≥ 100 mm - Metal pipes insulated elastomer****A.1.15.1****Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap**

Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless-) steel / cast iron	≤ Ø 22	≥ 1.0	Kaiflex ST (min. class B-s3, d0 B _L -s3, d0)	9 - 32	LS 400 / CS	Multiwrap (2 layers)	EI 90 C/U, E 120 C/U
				32			EI 120 C/U
	≤ Ø 54	≥ 1.5		13 - 32			EI 30 C/U, E 120 C/U
				32			EI 60 C/U, E 120 C/U
	≤ Ø 114.3	≥ 3.6		13			EI 45 C/U, E 120 C/U
				13 - 32			
	≤ Ø 168.3	≥ 4.5		32			EI 60 C/U, E 120 C/U



A.1.15**Multimortar - ≥ 100 mm - Metal pipes insulated elastomer****A.1.15.2****Copper and steel pipes - ArmaFlex Protect LS 400 / CS**Front view

Drawing: FW.E-CU-MM1.2.25

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 U/C
	$\leq \varnothing 54$	≥ 1.5		25		EI 90 C/U, E 120 C/U



A.1.16 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes uninsulated

A.1.16.1 Copper and steel pipes - Multitherm Bandage



Drawing: FW.E-CU-MM2.5.10-B2.1.20

Services	Pipe dimensions (mm)		Multitherm Bandage	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	LI 150 two layers (two wires)	EI 60 C/U, E 120 C/U



A.1.17**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Metal pipes uninsulated****A.1.17.1****Copper and steel pipes - Multitherm Bandage**Front view

Drawing: FW.E-CU-MM3.4.10-B2.1.20

Services	Pipe dimensions (mm)		Multitherm Bandage	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	LI 150 two layers (two wires)	EI 60 C/U, E 120 C/U

A.1.18**Multimortar - ≥ 100 mm - Metal pipes uninsulated****A.1.18.1****Copper and steel pipes - Multimastic SP**

Front view





Drawing: FW.E-ST-SPC-MM1.2.10



Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0	Multimastic SP	1.5 WFT	LI 200	EI 60 C/U, E 120 C/U
(Stainless) Steel / cast iron	$\leq \varnothing 16$	≥ 1.0				EI 90 C/U
	$\leq \varnothing 26.9$	≥ 2.6				EI 90 C/U, E 120 C/U
	$\leq \varnothing 42.4$	≥ 3.2				EI 60 C/U, E 120 C/U
	$\leq \varnothing 60.3$	≥ 3.6				

A.1.18**Multimortar - ≥ 100 mm - Metal pipes uninsulated****A.1.18.2****Copper and steel pipes - Multisealant GR**

Front view





Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
(Stainless) Steel / cast iron	$\leq \varnothing 26.9$	≥ 2.6	Multisealant GR	1.5 WFT	LI 200	EI 90 C/U, E 120 C/U
	$\leq \varnothing 60.3$	≥ 3.6				

A.1.18**Multimortar - ≥ 100 mm - Metal pipes uninsulated****A.1.18.3****Copper and steel pipes - Multidisc**


Drawing: FW.E-CU-M2-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0	Multidisc	EI 45 C/U, E 120 C/U
(Stainless) Steel / cast iron	$\leq \varnothing 17.2$			EI 90 C/U

A.1.18**Multimortar - ≥ 100 mm - Metal pipes uninsulated****A.1.18.4****Copper and steel pipes - Multitherm Bandage**

Drawing: FW.E-ST-MM1-B2.3.21

Services	Pipe dimensions (mm)		Multitherm Bandage	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	LI 150 two layers (two wires)	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5	LI 150 two layers (two wires) + LI 300 one layer (two wires)	EI 45 C/U, E 120 C/U
	$\leq \varnothing 88.9$	≥ 2.0		EI 30 C/U, E 120 C/U

A.1.19**Multimortar + Multimastic FB - ≥ 100 mm - Busbars****A.1.19.1****Single busbar - LI 300**


Services	Service dimensions		Insulation			Classification
	Outside	Conductor	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. $6 \times \leq 200$ mm width (per busbar)	Multimastic FB	50	LI 300 / CI	EI 60

A.1.19


Multimortar + Multimastic FB - ≥ 100 mm - Busbars

A.1.19.1

Single busbar - LI 300



Drawing: FW.E-1BB-MM2.5.20.LI300

A.1.19**Multimortar + Multimastic FB - ≥ 100 mm - Busbars****A.1.19.2****Single busbar - LI 400**Side view

Drawing: FW.E-1BB-MM2.5.20.LI300


Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120

A.1.19


Multimortar + Multimastic FB - ≥ 100 mm - Busbars

A.1.19.2

Single busbar - LI 400



Drawing: FW.E-1BB-MM2.5.20.LI300

A.1.19**Multimortar + Multimastic FB - ≥ 100 mm - Busbars****A.1.19.3****Multiple busbars - LI 300**

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500$ mm	max. $6 \times \leq 200$ mm width (per busbar)	Multimastic FB	50	LI 300 / CI	EI 60


A.1.19

Multimortar + Multimastic FB - ≥ 100 mm - Busbars


A.1.19.3

Multiple busbars - LI 300

Front view



Drawing: FW.E-2BB-MM2.2.20.LI300

A.1.19**Multimortar + Multimastic FB - ≥ 100 mm - Busbars****A.1.19.4****Multiple busbars - LI 400**

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500$ mm	max. $6 \times \leq 200$ mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


A.1.19

Multimortar + Multimastic FB - ≥ 100 mm - Busbars

A.1.19.4


Multiple busbars - LI 400

Front view




Drawing: FW.E-2BB-MM2.5.20

**A.1.20 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Busbars**
A.1.20.1 Single busbar - LI 300




Services	Service dimensions		Insulation			Classification
	Outside	Conductor	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 300 / CI	EI 60

- A.1.20 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Busbars**
- A.1.20.1 Single busbar - LI 300**




Drawing: FW.E-1BB-MM3.4.20.LI300

A.1.20 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm - Busbars
A.1.20.2 Single busbar - LI 400




Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Single busbar	≤ 150 x 250 mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120

- A.1.20 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -**
Busbars
A.1.20.2 Single busbar - LI 400




Drawing: FW.E-1BB-MM3.4.10

A.1.20**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Busbars****A.1.20.3****Multiple busbars - LI 300**


Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Double busbar	≤ 150 x 500 mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 300 / CI	EI 60

**A.1.20 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Busbars**
A.1.20.3 Multiple busbars - LI 300

Front view



Drawing: FW.E-2BB-MM3.4.20.LI300


A.1.20**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Busbars****A.1.20.4****Multiple busbars - LI 400**

Drawing: FW.E-2BB-MM3.4.20


Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500 \text{ mm}$	max. $6 \times \leq 200 \text{ mm}$ width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120

**A.1.20 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Busbars**
A.1.20.4 Multiple busbars - LI 400

Front view



Drawing: FW.E-2BB-MM3.4.20

A.1.21**Multimortar - ≥ 100 mm - Busbars****A.1.21.1****Single busbar - LI 300**


Services	Service dimensions		Insulation			Classification
	Outside	Conductor	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. $6 \times \leq 200$ mm width (per busbar)	Multimastic FB	50	LI 300 / CI	EI 60

A.1.21


Multimortar - ≥ 100 mm - Busbars

A.1.21.1

Single busbar - LI 300



Drawing: FW.E-1BB-MM1.2.20.LI300

A.1.21**Multimortar - ≥ 100 mm - Busbars****A.1.21.2****Single busbar - LI 400**Side view


Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120

A.1.21


Multimortar - ≥ 100 mm - Busbars

A.1.21.2

Single busbar - LI 400



Drawing: FW.E-1BB-MM1.2.20


A.1.21**Multimortar - ≥ 100 mm - Busbars****A.1.21.3****Multiple busbars - LI 300**

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Double busbar	≤ 150 x 500 mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 300 / CI	EI 60


A.1.21 Multimortar - ≥ 100 mm - Busbars

A.1.21.3 Multiple busbars - LI 300

Front view



Drawing: FW.E-2BB-MM1.2.20.LI300

A.1.21**Multimortar - ≥ 100 mm - Busbars****A.1.21.4****Multiple busbars - LI 400**

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductor	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500 \text{ mm}$	max. 6 x $\leq 200 \text{ mm}$ width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


A.1.21

Multimortar - ≥ 100 mm - Busbars

A.1.21.4

Multiple busbars - LI 400

Front view



Drawing: FW.E-2BB-MM1.2.20



A.1.22

Multimortar + Multimastic FB - ≥ 100 mm - Multiple services

A.1.22.1



Airconditioning set - Multicollar Slim

Front view





Drawing: FW.E-MC30-MLP5-MM2.5.40

Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer diameter	Wall thickness	Type	Thickness (mm)	Configuration		
Set of airconditioning pipes	$2x \leq \emptyset 15$	1.5	PE foam	≥ 6	LS 400 / CS LI 400 / CI	Multicollar Slim	EI 60 C/U E 120 C/U
PVC-U / PVC-C	$\leq \emptyset 40$	3.0	-	-	-		EI 60 U/U E 120 U/U
Telecommunication cable	UTP Cat 5/6	-	-	-	-		EI 60
Sheathed cable	$\leq YMVK 5 \times 2.5 \text{ mm}^2$	-	-	-	-		E 120

A.1.22**Multimortar + Multimastic FB - ≥ 100 mm - Multiple services****A.1.22.2****Multiple plastic pipes - Multicollar *Slim* double**

Drawing: FW.E-MC60-MLP3-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	$3 \times \leq \emptyset 110$	2.7	Multicollar <i>Slim</i> double	EI 90 U/C, E 120 U/C

A.1.22**Multimortar + Multimastic FB - ≥ 100 mm - Multiple services****A.1.22.3****Multiple Multilayer pipes (MLC) - Multicollar *Slim***Front view



Services	Pipe dimensions (mm)			Insulation			Product	Classification
	Outer diameter	Wall thickness	No. of pipes	Type	Thickness (mm)	Configuration		
Multilayer pipe (MLC)	$\leq \varnothing 15$	2.0	≤ 12	PE foam	≤ 6	LS 400 / CS LI 400 / CI	Multicollar <i>Slim</i>	EI 30 U/C E 120 U/C

A.1.23 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -

Multiple services

A.1.23.1 Airconditioning set - Multicollar Slim

Front view





Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer diameter	Wall thickness	Type	Thickness (mm)	Configuration		
Set of airconditioning pipes	2x ≤ Ø 15	1.5	PE foam	≥ 6	LS 400 / CS LI 400 / CI	Multicollar Slim	EI 60 C/U E 120 C/U
PVC-U / PVC-C	≤ Ø 40	3.0	-	-	-		EI 60 U/U E 120 U/U
Telecommunication cable	UTP Cat 5/6	-	-	-	-		EI 60
Sheathed cable	≤ YMVK 5 x 2.5 mm ²	-	-	-	-		E 120

A.1.23 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -

Multiple services

A.1.23.2 Multiple plastic pipes - Multicollar *Slim* double

Front view





Drawing: FW.E-MC60-MLP3-MM3.4.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	$3 \times \leq \emptyset 110$	2.7	Multicollar <i>Slim</i> double	EI 90 U/C, E 120 U/C

**A.1.23 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -
Multiple services**
A.1.23.3 Multiple Multilayer pipes (MLC) - Multicollar Slim

Front view





Services	Pipe dimensions (mm)			Insulation			Product	Classification
	Outer diameter	Wall thickness	No. of pipes	Type	Thickness (mm)	Configuration		
Multilayer pipe (MLC)	≤ Ø 15	2.0	≤ 12	PE foam	≤ 6	LS 400 / CS LI 400 / CI	Multicollar Slim	EI 30 U/C E 120 U/C

A.1.24 Multimortar - ≥ 100 mm - Multiple services



A.1.24.1 Airconditioning set - Multicollar Slim

Front view



Drawing: FW.E-MC30-MLP5-MM1.2.40

Services	Pipe dimensions (mm)		Insulation			Product	Classification
	Outer diameter	Wall thickness	Type	Thickness (mm)	Configuration		
Set of airconditioning pipes	$2x \leq \emptyset 15$	1.5	PE foam	≥ 6	LS 400 / CS LI 400 / CI	Multicollar Slim	EI 60 C/U E 120 C/U
PVC-U / PVC-C	$\leq \emptyset 40$	3.0	-	-	-		EI 60 U/U E 120 U/U
Telecommunication cable	UTP Cat 5/6	-	-	-	-		EI 60
Sheathed cable	$\leq YMVK 5 \times 2.5 \text{ mm}^2$	-	-	-	-		E 120

A.1.24**Multimortar - ≥ 100 mm - Multiple services****A.1.24.2****Multiple plastic pipes - Multicollar *Slim* double**



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	$3 \times \leq \emptyset 110$	2.7	Multicollar <i>Slim</i> double	EI 90 U/C, E 120 U/C

A.1.24

Multimortar - ≥ 100 mm - Multiple services

A.1.24.3



Multiple Multilayer pipes (MLC) - Multicollar Slim



Services	Pipe dimensions (mm)			Insulation			Product	Classification
	Outer diameter	Wall thickness	No. of pipes	Type	Thickness (mm)	Configuration		
Multilayer pipe (MLC)	$\leq \varnothing 15$	2.0	≤ 12	PE foam	≤ 6	LS 400 / CS LI 400 / CI	Multicollar Slim	EI 30 U/C E 120 U/C

A.1.25**Multimortar + Multimastic FB - ≥ 100 mm - Gas pipes****A.1.25.1****Multiple Corrugated Stainless Steel Tube (CSST) gas pipes - Multitherm Bandage**

Front view





Drawing: FW.E-CT-B2-MM2.5.10

Services	Pipe dimensions (mm)		Multitherm Bandage	Classification
	Outer dimension	Wall thickness		
Corrugated stainless steel tube (CSST) gas pipes in wire mesh cable tray	≤ Ø 19.9	≤ 3	LI 75 one layer (one wire)	EI 60 U/C
	≤ Ø 40.8	≤ 3		
	≤ Ø 60.3	≤ 1		

A.1.26**Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -****Gas pipes****A.1.26.1****Multiple Corrugated Stainless Steel Tube (CSST) gas pipes - Multitherm Bandage**

Front view





Drawing: FW.E-CT-B2-MM3.4.10

Services	Pipe dimensions (mm)		Multitherm Bandage	Classification
	Outer dimension	Wall thickness		
Corrugated stainless steel tube (CSST) gas pipes in wire mesh cable tray	≤ Ø 19.9	≤ 3	LI 75 one layer (one wire)	EI 60 U/C
	≤ Ø 40.8	≤ 3		
	≤ Ø 60.3	≤ 1		



A.1.27**Multimortar ≥ 100 mm - Gas pipes****A.1.27.1****Multiple Corrugated Stainless Steel Tube (CSST) gas pipes - Multitherm Bandage**

Front view



Drawing: FW.E-CT-B2-MM1.2.10

Services	Pipe dimensions (mm)		Multitherm Bandage	Classification
	Outer dimension	Wall thickness		
Corrugated stainless steel tube (CSST) gas pipes in wire mesh cable tray	≤ Ø 19.9	≤ 3	LI 75 one layer (one wire)	EI 60 U/C
	≤ Ø 40.8	≤ 3		
	≤ Ø 60.3	≤ 1		

A.1.28**Multimortar + Multimastic FB - ≥ 100 mm - Ducting****A.1.28.1****Rectangular duct - Multicollar *Slim***



Drawing: FW.E-MC30-AD-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rectangular plastic duct	$\leq 220 \times 90$	1.0	Multicollar <i>Slim</i>	EI 45 U/C
		2.0		EI 120 U/C

A.1.29 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm -

Ducting

A.1.29.1 Rectangular duct - Multicollar *Slim*





Drawing: FW.E-MC30-AD-MM3.4.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rectangular plastic duct	≤ 220 x 90	1.0	Multicollar <i>Slim</i>	EI 45 U/C
		2.0		EI 120 U/C


A.1.30 Multimortar - ≥ 100 mm - Ducting

A.1.30.1 Rectangular duct - Multicollar *Slim*





Drawing: FW.E-MC30-AD-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rectangular plastic duct	≤ 220 x 90	1.0	Multicollar <i>Slim</i>	EI 45 U/C
		2.0		EI 120 U/C

B.1.1**Multimortar - ≥ 100 mm - Cables, trays and conduits****B.1.1.1****Cables, trays and conduits**


Drawing: RF.E-CT-EC-ECB-PC-MM1.2.10

Services	Classification
Metal cable ladders	
Metal (non-)perforated cable trays	EI 120, E 180
Steel wire mesh cable trays (baskets)	
Cables $\leq \varnothing 21$ mm (single or bundled)	EI 120, E 180
Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	EI 120, E 240
Cables $\leq \varnothing 50$ mm	EI 60, E 120
Plastic conduits $\leq \varnothing 16$ mm	EI 180 U/C, E 240 U/C
Non sheathed cables $\leq \varnothing 24$ mm	EI 45, E 120

B.1.1**Multimortar - ≥ 100 mm - Cables, trays and conduits****B.1.1.2****Plastic pipes with cables - Multiwrap**Bottom view

Drawing: RF.E-PPEC-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	$\leq \varnothing 110$	2.7 - 10	Multiwrap (2 layers)	EI 180 U/C
PP				
PVC(-U/-C)				
Cables $\leq \varnothing 21$ mm (single or bundled)	-	-	-	EI 180
Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	-	-	-	
Cables $\leq \varnothing 50$ mm	-	-	-	EI 60, E 120



B.1.2**Multimortar - ≥ 150 mm - Cables, trays and conduits****B.1.2.1****Cables, trays and conduits**

Drawing: RF.E-CT-EC-ECB-PC-MM1.3.10

Services	Classification
Metal cable ladders	
Metal (non-)perforated cable trays	EI 120, E 180
Steel wire mesh cable trays (baskets)	
Cables $\leq \varnothing 21$ mm (single or bundled)	EI 120, E 180
Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	EI 120, E 240
Cables $\leq \varnothing 50$ mm	EI 60, E 120
Plastic conduits $\leq \varnothing 16$ mm	EI 180 U/C, E 240 U/C
Non sheathed cables $\leq \varnothing 24$ mm	EI 45, E 120

B.1.2 Multimortar - ≥ 150 mm - Cables, trays and conduits

B.1.2.2 Plastic pipes with cables - Multiwrap




Drawing: RF.E-PPEC-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE(-HD) / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7 - 10	Multiwrap (2 layers)	EI 180 U/C
PP				
PVC(-U/-C)				
Cables ≤ Ø 21 mm (single or bundled)	-	-	-	EI 180
Cables ≤ Ø 21 mm in a tied bundle ≤ Ø 100 mm	-	-	-	
Cables ≤ Ø 50 mm	-	-	-	EI 60, E 120

B.1.3 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

B.1.3.1 Cables, trays and conduits - Multimastic FB





Drawing: RF.E-CT-EC-ECB-PC-MM2.5.10

Services	Classification
Metal cable ladders	
Metal (non-)perforated cable trays	EI 90, E 180
Steel wire mesh cable trays (baskets)	
Cables ≤ Ø 21 mm (single or bundled)	EI 60, E 180
Cables ≤ Ø 21 mm in a tied bundle ≤ Ø 100 mm	EI 120, E 180
Cables ≤ Ø 50 mm	EI 60, E 120
Plastic conduits ≤ Ø 16 mm	EI 180 U/C
Non sheathed cables ≤ Ø 24 mm	EI 45, E 120

B.1.3 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

B.1.3.2 Cables, trays and conduits - Multitherm Bandage - Bottom of floor





Drawing: RF.E-CT-MM2.5.10-B1.1.10

Services	Insulation (mm)	Classification
Metal cable ladders	LI 150 Multitherm Bandage bottom of floor (two wires)	EI 60, E 120
Metal (non-)perforated cable trays		
Steel wire mesh cable trays (baskets)		
Cables $\leq \varnothing 21$ mm (single or bundled)		
Plastic conduit $\leq \varnothing 16$ mm		EI 60 U/C, E 120 U/C


B.1.3 Multimortar + Multimastic FB - ≥ 100 mm - Cables, trays and conduits

B.1.3.3 Cables, trays and conduits - Multitherm Bandage - Top of floor



Drawing: RF.E-CT-MM2.5.10-B3.1.10

Services	Insulation (mm)	Classification
Metal cable ladders	LI 150 Multitherm Bandage top of floor	EI 90, E 120
Metal (non-)perforated cable trays		
Steel wire mesh cable trays (baskets)		
Cables ≤ Ø 21 mm (single or bundled)		
Plastic conduit ≤ Ø 16 mm		EI 90 U/C, E 120 U/C



B.1.4**Multimortar + Multimastic FB - ≥ 150 mm - Cables, trays and conduits****B.1.4.1****Cables, trays and conduits - Multimastic FB**

Drawing: RF.E-CT-EC-ECB-PC-MM2.7.10

Services	Classification
Metal cable ladders	
Metal (non-)perforated cable trays	EI 120
Steel wire mesh cable trays (baskets)	
Cables $\leq \varnothing 21$ mm (single or bundled)	EI 120
Cables $\leq \varnothing 21$ mm in a tied bundle $\leq \varnothing 100$ mm	EI 120, E 240
Cables $\leq \varnothing 80$ mm	EI 90, E 120
Plastic conduits $\leq \varnothing 16$ mm	EI 180 U/C, E 240 U/C
Non sheathed cables $\leq \varnothing 24$ mm	EI 90, E 120
Non sheathed cables $\leq \varnothing 17$ mm	EI 120

B.1.4 Multimortar + Multimastic FB - ≥ 150 mm - Cables, trays and conduits

B.1.4.2 Cables, trays and conduits - Multitherm Bandage - Bottom of floor





Drawing: RF.E-CT-MM2.7.10-B1.1.10

Services	Insulation (mm)	Classification
Metal cable ladders	LI 150 Multitherm Bandage bottom of floor (two wires)	EI 60, E 120
Metal (non-)perforated cable trays		
Steel wire mesh cable trays (baskets)		
Cables ≤ Ø 21 mm (single or bundled)		
Plastic conduit ≤ Ø 16 mm		EI 60 U/C, E 120 U/C

B.1.4 Multimortar + Multimastic FB - ≥ 150 mm - Cables, trays and conduits

B.1.4.3 Cables, trays and conduits - Multitherm Bandage - Top of floor





Drawing: RF.E-CT-MM3.5.10-B3.1.10

Services	Insulation (mm)	Classification
Metal cable ladders	LI 150 Multitherm Bandage top of floor	EI 90, E 120
Metal (non-)perforated cable trays		
Steel wire mesh cable trays (baskets)		
Cables ≤ Ø 21 mm (single or bundled)		
Plastic conduit ≤ Ø 16 mm		EI 90 U/C, E 120 U/C

B.1.4 Multimortar + Multimastic FB - ≥ 150 mm - Cables, trays and conduits

B.1.4.4 Single PVC conduits - Multidisc





Drawing: RF.E-EP19-MM2.7.10

Services	Product	Allowed cables	Classification
Plastic conduits $\leq \varnothing 19$ mm with or without cables	Multidisc	UTP / F-UTP / F-STP / YMVK	EI 120 U/C

B.1.4 Multimortar + Multimastic FB - ≥ 150 mm - Cables, trays and conduits

B.1.4.5 Single cables - Multidisc





Drawing: RF.E-EC-MM2.7.10

Services	Product	Classification
Single electrical cables $\leq \varnothing 21$ mm	Multidisc	EI 90, E 120



B.1.4 Multimortar + Multimastic FB - ≥ 150 mm - Cables, trays and conduits

B.1.4.6 Multiple cables - Multidisc



Drawing: RF.E-ECB-MM2.7.10

Services	Product	Classification
Multiple electrical / telecommunication cables max. 15 pcs., max. $\leq \varnothing$ 25 mm	Multidisc	EI 120 U/C



B.1.5**Multimortar - ≥ 100 mm - Combustible pipes****B.1.5.1****Plastic pipes**

Drawing: RF.E-PP-MM1.2.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 40$	1.8 - 2.0	EI 90 U/C
		2.0	EI 120 U/C
		4.3	EI 240 U/C
		1.8 - 5.5	
		1.8 - 3.0	

B.1.5 Multimortar - ≥ 100 mm - Combustible pipes

B.1.5.2 Plastic pipes - Multicollar Slim




Drawing: RF.E-MC30-PP-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 110$	2.7	Multicollar Slim	EI 120 U/U
		2.7 - 6.6		EI 60 U/U, E 90 U/U
		2.7		EI 90 U/U
		2.4 - 6.3		EI 60 U/U
		2.7		EI 90 U/U
		2.4 - 6.3		EI 45 U/U, E 60 U/U

B.1.5 Multimortar - ≥ 100 mm - Combustible pipes

B.1.5.3 Plastic pipes - Multiwrap



Drawing: RF.E-PP-MW2-MM1.2.10



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 40$	2.0 - 3.7	Multiwrap (1 layer)	EI 240 U/U
PP		1.8 - 5.5		
PVC(-U-C)		2.0 - 3.7		
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 50$	3.0 - 4.6		EI 180 U/C
PP		2.9 - 4.6		
PVC(-U-C)		3.0 - 4.6		
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 110$	3.4 - 10.0	Multiwrap (2 layers)	EI 240 U/C
PP		2.7 - 6.3		
PVC(-U-C)		3.4 - 6.3		

B.1.5**Multimortar - ≥ 100 mm - Combustible pipes****B.1.5.3****Plastic pipes - Multiwrap**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 125	3.9 - 11.4	Multiwrap (3 layers)	EI 180 U/C
PP		4.8		EI 120 U/C
PVC(-U/-C)		4.8 - 11.4		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7	Multiwrap (4 layers)	EI 120 U/U
	≤ Ø 125	3.9		EI 240 U/U
	≤ Ø 160	4.9		EI 180 U/C
		4.9 - 14.6		EI 120 U/C
PP	≤ Ø 110	10.0		EI 240 U/U
	≤ Ø 125	3.1 - 11.4		EI 240 U/C
		11.4		EI 240 U/U
	≤ Ø 160	6.2		EI 180 U/C
PVC(-U/-C)		6.2 - 14.6		EI 90 U/C
≤ Ø 160	6.2	Multiwrap (4 layers) (both sides)	EI 120 U/C	
	6.2 - 14.6		EI 90 U/C	
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 160	9.5	Multiwrap (6 layers)	EI 240 U/U
PP	≤ Ø 160	14.6		EI 120 U/C

B.1.5 Multimortar - ≥ 100 mm - Combustible pipes

B.1.5.4 Plastic pipes (Silent) - Multicollar Slim





Drawing: RF.E-MC30-PPS-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Geberit Silent dB 20	≤ Ø 110	6.0	Multicollar Slim	EI 90 U/U

B.1.5 Multimortar - ≥ 100 mm - Combustible pipes

B.1.5.5 Plastic pipes (Silent) - Multiwrap

Bottom view



Drawing: RF.E-PPS-MM1.2.10



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rehau Raupiano Plus	$\leq \text{Ø} 50$	1.8	Multiwrap (1 layer)	EI 180 U/C
Wavin SiTech+				EI 240 U/U
Rehau Raupiano Plus				EI 180 U/U
Wavin SiTech+		2.0		EI 240 U/U
Poloplast PoloKal NG		3.2		EI 180 U/C
Geberit Silent dB 20		2.7		EI 180 U/C
Rehau Raupiano Plus	$\leq \text{Ø} 56$	3.4	Multiwrap (2 layers)	EI 180 U/C
Wavin SiTech+		2.7		EI 240 U/C
Poloplast PoloKal NG		6.0		EI 240 U/C
Geberit Silent dB 20				

B.1.5**Multimortar - ≥ 100 mm - Combustible pipes****B.1.5.5****Plastic pipes (Silent) - Multiwrap**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Poloplast PoloKal NG	$\leq \varnothing 125$	3.9	Multiwrap (4 layers)	EI 240 U/C
Rehau Raupiano Plus	$\leq \varnothing 160$			EI 180 U/C
Wavin SiTech+	4.9	Multiwrap (6 layers)	EI 240 U/C	
Rehau Raupiano Plus				

B.1.5 Multimortar - ≥ 100 mm - Combustible pipes

B.1.5.6 PP-R multiplayer pipes - Multicollar Slim





Drawing: RF.E-MC30-MLF-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Aquatherm Green	≤ Ø 50	6.9	Multicollar Slim	EI 90 U/C
Aquatherm Blue	≤ Ø 110	10.0		EI 60 U/C

B.1.6 Multimortar - ≥ 150 mm - Combustible pipes

B.1.6.1 Plastic pipes





Drawing: RF.E-PP-MM1.3.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 40$	1.8 - 2.0	EI 90 U/C
		2.0	EI 120 U/C
		4.3	EI 240 U/C
		1.8 - 5.5	
		1.8 - 3.0	



B.1.6 Multimortar - ≥ 150 mm - Combustible pipes

B.1.6.2 Plastic pipes - Multicollar Slim



Drawing: RF.E-MC30-PP-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification	
	Outer dimension	Wall thickness			
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7	Multicollar Slim	EI 120 U/U	
		2.7 - 3.1		EI 90 U/U	
		3.1 - 6.6		EI 60 U/U, E 90 U/U	
	≤ Ø 125	3.1		EI 120 U/C	
PP	≤ Ø 110	2.7		EI 90 U/U	
		2.7 - 6.3		EI 60 U/U	
PVC(-U/-C)		2.7		EI 90 U/U	
		2.7 - 6.3		EI 60 U/U	


B.1.6**Multimortar - ≥ 150 mm - Combustible pipes****B.1.6.3****Plastic pipes with elbow and U-shape collar - Multicollar Slim**

Drawing: RF.E-MC30u-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PVC(-U/-C)	≤ Ø 110	2.7	Multicollar Slim	EI 120 U/U
PE-HD / PE-X / ABS / SAN+PVC		2.7 - 6.6	Multicollar Slim double	EI 60 U/U, E 120 U/U

B.1.6 Multimortar - ≥ 150 mm - Combustible pipes

B.1.6.4 Plastic pipes - Multiwrap



Drawing: RF.E-PP-MW2-MM1.3.10



Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 40	2.0 - 3.7	Multiwrap (1 layer)	EI 240 U/U
PP		1.8 - 5.5		
PVC(-U-C)		2.0 - 3.7		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 50	3.0 - 4.6	Multiwrap (1 layer)	EI 180 U/U
PP		2.9 - 4.6		
PVC(-U-C)		3.0 - 4.6		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 110	3.4 - 10.0	Multiwrap (2 layers)	EI 240 U/C
PP		2.7 - 6.3		
PVC(-U-C)		3.4 - 6.3		

B.1.6**Multimortar - ≥ 150 mm - Combustible pipes****B.1.6.4****Plastic pipes - Multiwrap**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 125	3.9 - 11.4	Multiwrap (3 layers)	EI 180 U/C
PP		4.8		EI 120 U/C
PVC(-U/-C)		4.8 - 11.4		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7	Multiwrap (4 layers)	EI 120 U/U
	≤ Ø 125	3.9		EI 240 U/U
	≤ Ø 160	4.9		EI 180 U/C
		4.9 - 14.6		EI 120 U/C
PP	≤ Ø 110	10.0		EI 240 U/U
	≤ Ø 125	3.1 - 11.4		EI 240 U/C
		11.4		EI 240 U/U
	≤ Ø 160	6.2		EI 180 U/C
PVC(-U/-C)		6.2 - 14.6		EI 90 U/C
≤ Ø 160	6.2	Multiwrap (4 layers) (both sides)	EI 120 U/C	
	6.2 - 14.6		EI 90 U/C	
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 160	9.5	Multiwrap (6 layers)	EI 240 U/U
PP	≤ Ø 160	14.6		EI 120 U/C

B.1.6 Multimortar - ≥ 150 mm - Combustible pipes

B.1.6.5 Plastic pipes (Silent) - Multicollar Slim





Drawing: RF.E-MC30-PPS-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Geberit Silent dB 20	≤ Ø 110	6.0	Multicollar Slim	EI 90 U/U

B.1.6 Multimortar - ≥ 150 mm - Combustible pipes

B.1.6.6 Plastic pipes (Silent) - Multiwrap

Bottom view





Drawing: RF.E-PPS-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Rehau Raupiano Plus	$\leq \varnothing 50$	1.8	Multiwrap (1 layer)	EI 180 U/C
Wavin SiTech+				EI 240 U/U
Rehau Raupiano Plus				EI 180 U/U
Wavin SiTech+		2.0		EI 240 U/U
Poloplast PoloKal NG		3.2		EI 180 U/C
Geberit Silent dB 20		2.7		EI 180 U/C
Rehau Raupiano Plus	$\leq \varnothing 110$	3.4	Multiwrap (2 layers)	EI 180 U/C
Wavin SiTech+				EI 240 U/C
Poloplast PoloKal NG		6.0		EI 240 U/C
Geberit Silent dB 20				



B.1.6**Multimortar - ≥ 150 mm - Combustible pipes****B.1.6.6****Plastic pipes (Silent) - Multiwrap**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Poloplast PoloKal NG	≤ Ø 125	3.9	Multiwrap (4 layers)	EI 240 U/C
Rehau Raupiano Plus	≤ Ø 160			EI 180 U/C
Wavin SiTech+	4.9	Multiwrap (6 layers)	EI 240 U/C	
Rehau Raupiano Plus				

B.1.6**Multimortar - ≥ 150 mm - Combustible pipes****B.1.6.7****PP-R multiplayer pipes - Multicollar Slim**



Drawing: RF.E-MC30-MLF-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Aquatherm Green	≤ Ø 50	6.9		EI 90 U/C
Aquatherm Blue	≤ Ø 110	10.0	Multicollar Slim	EI 60 U/C

B.1.6**Multimortar - ≥ 150 mm - Combustible pipes****B.1.6.8****Beverage dispense tubing - Multicollar Slim**Bottom view



Drawing: RF.E-MC30-DCP52-MM1.3.10

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Hoses no.	Type	Thickness (mm)	Configuration		
Drinks tubing system	≤ Ø 145	≤ 52	Elastomeric foam	8 - 35	CS	Multicollar Slim	EI 120 U/C

B.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****B.1.7.1****Plastic pipes**Bottom view

Drawing: RF.E-PP50-MM2.5.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
PVC(-U/-C)	$\leq \varnothing 40$	1.8 - 3.0	EI 180 U/C



B.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****B.1.7.2****Plastic pipes - Multicollar Slim**

Drawing: RF.E-MC30-PP-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 110	2.7	Multicollar Slim	EI 120 U/U
PP		2.7 - 6.6		EI 60 U/U
PVC(-U/-C)		2.7 - 6.3		



B.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****B.1.7.3****Plastic pipes - Multiwrap**

Bottom view





Drawing: RF.E-PP-MW-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PVC(-U/-C)	$\leq \text{Ø} 110$	3.2	Multiwrap (2 layers)	EI 240 U/U
PP		10.0	Multiwrap (4 layers)	EI 180 U/U



B.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****B.1.7.4****Plastic pipes (Silent) - Multicollar Slim**

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Geberit Silent dB 20	$\leq \varnothing 110$	6.0	Multicollar Slim	EI 60 U/U

B.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****B.1.7.5****Plastic pipes (Silent) - Multiwrap**Bottom view



Drawing: RF.E-PPS-MW-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Poloplast PoloKal NG	≤ Ø 50	2.0	Multiwrap (2 layers)	EI 180 U/U
Geberit Silent dB 20	≤ Ø 56	3.2		
Poloplast PoloKal NG	≤ Ø 110	3.4		
Geberit Silent dB 20		6.0		
Poloplast PoloKal NG	≤ Ø 125	3.9	Multiwrap (4 layers)	EI 180 U/C

B.1.7**Multimortar + Multimastic FB - ≥ 100 mm - Combustible pipes****B.1.7.6****PP-R multiplayer pipes - Multicollar Slim**



Drawing: RF.E-MC30-MLF-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Aquatherm Green	$\leq \varnothing 50$	6.9	Multicollar Slim	EI 60 U/C
Aquatherm Blue	$\leq \varnothing 110$	10.0		

B.1.8**Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes****B.1.8.1****Plastic pipes**Bottom view



Drawing: RF.E-PP50-MM2.7.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
PVC(-U/-C)	$\leq \emptyset 40$	1.8 - 3.0	EI 240 U/C

B.1.8**Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes****B.1.8.2****Plastic pipes - Multicollar Slim**

Drawing: RF.E-MC30-PP-MM2.7.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	$\leq \varnothing 110$	2.7	Multicollar Slim	EI 120 U/U
		2.7 - 3.1		EI 120 U/C
PP	$\leq \varnothing 125$	3.1		
	$\leq \varnothing 110$	2.7 - 6.6		EI 60 U/U
PVC(-U/-C)		2.7 - 6.3		

B.1.8**Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes****B.1.8.3****Plastic pipes - Multiwrap**Bottom view



Drawing: RF.E-PP-MW-MM2.7.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
PVC(-U/-C)	≤ Ø 110	3.2	Multiwrap (2 layers)	EI 120 U/C
PE-HD / PE-X / ABS / SAN+PVC		2.7		EI 120 U/U
PP		10.0		EI 240 U/U

B.1.8 Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes



B.1.8.4 Plastic pipes - Multimastic SP

Bottom view



Drawing: RF.E-PP50-MSP1-MM2.7.10

Services	Pipe dimensions (mm)		Sealing (mm)	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	$\leq \text{Ø} 40$	3.7	Multimastic SP $\geq 10 \times 20$ (wxd)	EI 120 U/C
PP		1.8 - 3.7		
PVC(-U/-C)		2.0		



B.1.8**Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes****B.1.8.5****Plastic pipes - Multisealant GR**Bottom view

Drawing: RF.E-PP50-G1-MM2.7.10

Services	Pipe dimensions (mm)		Sealing (mm)	Classification
	Outer dimension	Wall thickness		
PE-HD / PE-X / ABS / SAN+PVC	≤ Ø 40	2.4 - 10	Multisealant GR ≥ 15 x 20 (wxd)	EI 120 U/U
	≤ Ø 110	2.7 - 10		
PP	≤ Ø 40	2.3 - 10	Multisealant GR ≥ 15 x 20 (wxd)	EI 120 U/U
	≤ Ø 110	2.7 - 10		
PVC(-U/-C)	≤ Ø 40	2.4 - 10	Multisealant GR ≥ 15 x 20 (wxd)	EI 120 U/U
	≤ Ø 110	2.7 - 10		



B.1.8 Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes

B.1.8.6 Plastic pipes (Silent) - Multicollar Slim





Drawing: RF.E-MC30-PPS-MM2.7.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Geberit Silent dB 20	$\leq \varnothing 110$	6.0	Multicollar Slim	EI 60 U/U

B.1.8**Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes****B.1.8.7****Plastic pipes (Silent) - Multiwrap**Bottom view



Drawing: RF.E-PPS-MW-MM2.7.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Poloplast PoloKal NG	$\leq \varnothing 50$	2.0	Multiwrap (2 layers)	EI 180 U/U
Geberit Silent dB 20	$\leq \varnothing 56$	3.2		
Poloplast PoloKal NG	$\leq \varnothing 110$	3.4		
Geberit Silent dB 20		6.0		
Poloplast PoloKal NG	$\leq \varnothing 125$	3.9	Multiwrap (4 layers)	EI 180 U/C

B.1.8**Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes****B.1.8.8****PP-R multiplayer pipes - Multicollar Slim**

Drawing: RF.E-MC30-MLF-MM2.7.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Aquatherm Green	$\leq \varnothing 50$	6.9	Multicollar Slim	EI 60 U/C
Aquatherm Blue	$\leq \varnothing 110$	10.0		



B.1.8**Multimortar + Multimastic FB - ≥ 150 mm - Combustible pipes****B.1.8.9****Beverage dispense tubing - Multicollar Slim**

Drawing: RF.E-DCP25-MM2.2.10

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Hoses no.	Type	Thickness (mm)	Configuration		
Drinks tubing system	≤ Ø 145	≤ 52	Elastomeric foam	8 - 35	CS	Multicollar Slim	EI 120 U/C

B.1.9 Multimortar - ≥ 100 mm - Multilayer pipes (MLC)

B.1.9.1 Multilayer pipes (MLC)





Drawing: RF.E-MLA-MM1.2.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
Multilayer pipes (MLC)	≤ Ø 75	6.0	EI 180 U/C, E 240 U/C

B.1.10 Multimortar - ≥ 150 mm - Multilayer pipes (MLC)

B.1.10.1 Multilayer pipes (MLC)





Drawing: RF.E-MLA-MM1.3.10

Services	Pipe dimensions (mm)		Classification
	Outer dimension	Wall thickness	
Multilayer pipes (MLC)	≤ Ø 75	6.0	EI 180 U/C, E 240 U/C

B.1.10 Multimortar - ≥ 150 mm - Multilayer pipes (MLC)

B.1.10.2 Multilayer pipes (MLC) - Multidisc





Drawing: RF.E-MLA-M1-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	≤ Ø 16	2.0	Muldisc bottom of floor	EI 120 U/C



B.1.10 Multimortar - ≥ 150 mm - Multilayer pipes (MLC)

B.1.10.3 Multilayer pipes (MLC) - ArmaFlex Protect LS 400 / CS





Drawing: RF.E-MLA-MM1.3.22

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Multilayer pipes (MLC)	≤ Ø 26	3.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 U/C
	≤ Ø 75	6.0				

B.1.11**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****B.1.11.1****Multilayer pipes (MLC) - Multisealant GR**Bottom view



Drawing: RF.E-MLA-G1-MM2.5.10

Services	Pipe dimensions (mm)		Sealing (mm)	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	$\leq \varnothing 32$	3.0	Multisealant GR $\geq 15 \times 20$ (wxd)	EI 30 U/C, E 90 U/C

B.1.11**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****B.1.11.2****Multilayer pipes (MLC) - Elastomer LS 400 / CS - Multisealant GR**



Drawing: RF.E-MLA-G1-MM2.5.22

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Multilayer pipes (MLC)	≤ Ø 75	6.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	9 - 32	LS 400 / CS	Multisealant GR ≥ 15 x 20 (wxd)	EI 90 U/C

B.1.11**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****B.1.11.3****Multilayer pipes (MLC) - PE foam - Multisealant GR**



Drawing: RF.E-MLA_pr-G1-MM2.5.23

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Multilayer pipes (MLC)	≤ Ø 32	3.0	Henco PE foam	≤ 6	LS 300 / CS LI 300 / CI	Multisealant GR ≥ 15 x 20 (wxd)	EI 30 U/C, E 90 U/C

B.1.11**Multimortar + Multimastic FB - ≥ 100 mm - Multilayer pipes (MLC)****B.1.11.4****Multilayer pipes (MLC) - ArmaFlex Protect LS 400 / CS**Bottom view

Drawing: RF.E-MLA-MM2.5.22

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Multilayer pipes (MLC)	$\leq \varnothing 26$	3.0	ArmaFlex Protect	20	LS 400 / CS	EI 120 U/C
	$\leq \varnothing 75$	6.0		25		

B.1.12**Multimortar + Multimastic FB - ≥ 150 mm - Multilayer pipes (MLC)****B.1.12.1****Multilayer pipes (MLC) - Multisealant GR**

Drawing: RF.E-MLA-MM2.3.10

Services	Pipe dimensions (mm)		Sealing (mm)	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	≤ Ø 32	3.0	Multisealant GR ≥ 15 x 20 (wxd)	EI 30 U/C, E 90 U/C


B.1.12

Multimortar + Multimastic FB - ≥ 150 mm - Multilayer pipes (MLC)


B.1.12.2

Multilayer pipes (MLC) - Multidisc

Bottom view





a - Overlay size
(Minimum 10 mm overlay)
b - Mulcol® Multidisc





Drawing: RF.E-MLA-M1-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC)	≤ Ø 16	2.0	Multidisc bottom of floor	EI 120 U/C

B.1.12**Multimortar + Multimastic FB - ≥ 150 mm - Multilayer pipes (MLC)****B.1.12.3****Multilayer pipes (MLC) - Stone wool LS 400 / CS**Bottom view



Drawing: RF.E-MLA-MM2.7.20

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Multilayer pipes (MLC)	$\leq \varnothing 20$	2.0	Stone wool $(\geq 80 \text{ kg/m}^3)$	≥ 25	LS 400 / CS	EI 120 U/C
	$\leq \varnothing 90$	7.0				

B.1.12**Multimortar + Multimastic FB - ≥ 150 mm - Multilayer pipes (MLC)****B.1.12.4****Multilayer pipes (MLC) - Elastomer LS 400 / CS - Multisealant GR**



Drawing: RF.E-MLA-MM2.2.22

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Multilayer pipes (MLC)	≤ Ø 75	6.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	9 - 32	LS 400 / CS	Multisealant GR ≥ 15 x 20 (wxd)	EI 90 U/C

B.1.12**Multimortar + Multimastic FB - ≥ 150 mm - Multilayer pipes (MLC)****B.1.12.5****Multilayer pipes (MLC) - PE foam - Multisealant GR**



Drawing: RF.E-MLA_pr-MM2.2.23

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Multilayer pipes (MLC)	≤ Ø 32	3.0	Henco PE foam	≤ 6	LS 300 / CS LI 300 / CI	Multisealant GR ≥ 15 x 20 (wxd)	EI 30 U/C, E 90 U/C

B.1.12**Multimortar + Multimastic FB - ≥ 150 mm - Multilayer pipes (MLC)****B.1.12.6****Multilayer pipes (MLC) - ArmaFlex Protect LS 400 / CS**Bottom view



Drawing: RF.E-MLA-MM2.2.22

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Multilayer pipes (MLC)	$\leq \varnothing 26$	3.0	ArmaFlex Protect	20	LS 400 / CS	EI 120 U/C
	$\leq \varnothing 75$	6.0		25		

B.1.13**Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool****B.1.13.1****Copper and steel pipes - Stone wool LS 400 / CS**Bottom view



Drawing: RF.E-CU-MM1.2.20

Services	Pipe dimensions (mm)		Insulation			Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool $(\geq 80 \text{ kg/m}^3)$	25	LS 400 / CS	EI 180 C/U	
	$\leq \varnothing 54$	≥ 1.5					
(Stainless) Steel / cast iron	$\leq \varnothing 324$	≥ 3.7		30		EI 60 C/U E 120 C/U	
		≥ 6.3					

B.1.13**Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool****B.1.13.2****Copper and steel pipes - Stone wool LI 400 / CI**Bottom view



Drawing: RF.E-CU-MM1.2.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m³)	25	LI 400 / CI	EI 180 C/U	
	$\leq \varnothing 54$	≥ 1.5				EI 240 C/U	
(Stainless) Steel / cast iron	$\leq \varnothing 40$	≥ 1.0		30		EI 120 C/U	
	$\leq \varnothing 114.3$	≥ 3.6				E 180 C/U	
	$\leq \varnothing 40$	≥ 1.0				EI 240 C/U	
	$\leq \varnothing 219$	≥ 4.0				EI 120 C/U	
						E 180 C/U	

B.1.13**Multimortar - ≥ 100 mm - Metal pipes insulated mineral wool****B.1.13.3****Copper and steel pipes - Glass wool LS 400 / CS**Bottom view



Drawing: RF.E-ST-MM1.2.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification		
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
(Stainless) Steel / cast iron	$\leq \varnothing 40$	≥ 2.0	Isover Climclover Glass wool $(\geq 33 \text{ kg/m}^3)$	25	LI 400 / CI	EI 120 C/U		
	$\leq \varnothing 114.3$	≥ 3.6				EI 90 C/U		
	$\leq \varnothing 219$	≥ 4.0		30		E 120 C/U		
						EI 60 C/U		
						E 120 C/U		

B.1.14**Multimortar - ≥ 150 mm - Metal pipes insulated mineral wool****B.1.14.1****Copper and steel pipes - Stone wool LS 400 / CS**Bottom view



Drawing: RF.E-CU-MM1.3.20

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m ³)	≥ 25	LS 425 / CS	EI 180 C/U E 240 C/U
	$\leq \varnothing 54$	≥ 1.5		≥ 25		EI 120 C/U E 240 C/U
(Stainless) Steel / cast iron	$\leq \varnothing 114.3$	≥ 3.6		≥ 30	LS 400 / CS	EI 120 C/U E 180 C/U
		≥ 3.7				EI 120 C/U E 240 C/U
	$\leq \varnothing 324$	≥ 6.3		≥ 50	CS	EI 240 C/U

B.1.14**Multimortar - ≥ 150 mm - Metal pipes insulated mineral wool****B.1.14.2****Copper and steel pipes - Stone wool LI 400 / CI**Bottom view

Drawing: RF.E-CU-MM1.3.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool $(\geq 80 \text{ kg/m}^3)$	≥ 25	LI 400 / CI	EI 240 C/U
	$\leq \varnothing 54$	≥ 1.5				
(Stainless) Steel / cast iron	$\leq \varnothing 40$	≥ 1.0	Stone wool $(\geq 80 \text{ kg/m}^3)$	≥ 30	LI 400 / CI	EI 240 C/U
	$\leq \varnothing 114.3$	≥ 3.6				
	$\leq \varnothing 219$	≥ 4.0				

B.1.14**Multimortar - ≥ 150 mm - Metal pipes insulated mineral wool****B.1.14.3****Copper and steel pipes - Glass wool LI 400 / Cl**Bottom view



Drawing: RF.E-ST-MM1.3.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification		
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
(Stainless) Steel / cast iron	$\leq \varnothing 40$	≥ 2.0	Isover Climclover Glass wool (≥ 33 kg/m ³)	≥ 25	LI 400 / Cl	EI 120 C/U		
	$\leq \varnothing 114.3$	≥ 3.6				EI 90 C/U		
	$\leq \varnothing 219$	≥ 4.0		≥ 30		E 120 C/U		
						EI 60 C/U		
						E 120 C/U		

B.1.15 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated mineral wool

B.1.15.1 Copper and steel pipes - Stone wool LS 400 / CS

Bottom view





Drawing: RF.E-CU-MM2.5.20

Services	Pipe dimensions (mm)		Insulation			Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m ³)	25	LS 400 / CS	EI 120 C/U E 180 C/U	
	$\leq \varnothing 54$	≥ 1.5				EI 60 C/U E 120 C/U	
(Stainless) Steel / cast iron	$\leq \varnothing 324$	≥ 3.7		30		EI 120 C/U E 180 C/U	

B.1.15 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated mineral wool

B.1.15.2 Copper and steel pipes - Stone wool LI 400 / CI

Bottom view





Drawing: RF.E-CU-MM2.5.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m ³)	25	LI 400 / CI	EI 120 C/U E 180 C/U
	$\leq \varnothing 54$	≥ 1.5				EI 180 C/U
(Stainless) Steel / cast iron	$\leq \varnothing 40$	≥ 1.0		30		EI 120 C/U
	$\leq \varnothing 114.3$	≥ 3.6				E 180 C/U
	$\leq \varnothing 219$	≥ 4.0				

B.1.15 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated mineral wool



B.1.15.3 Copper and steel pipes - Glass wool LI 400 / Cl

Bottom view



Drawing: RF.E-ST-MM2.5.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification		
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
(Stainless) Steel / cast iron	$\leq \emptyset 40$	≥ 2.0	Glass wool (≥ 33 kg/m ³)	25	LI 400 / Cl	EI 120 C/U		
	$\leq \emptyset 114.3$	≥ 3.6				EI 90 C/U		
	$\leq \emptyset 219$	≥ 4.0		30		E 120 C/U		
						EI 60 C/U		
						E 120 C/U		



B.1.16**Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated mineral wool****B.1.16.1****Copper and steel pipes - Stone wool LS 400 / CS**Bottom view

Drawing: RF.E-CU-MM2.7.20

Services	Pipe dimensions (mm)		Insulation			Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m ³)	25	LS 400 / CS	EI 180 C/U	
	$\leq \varnothing 54$	≥ 1.5				EI 60 C/U E 120 C/U	
(Stainless) Steel / cast iron	$\leq \varnothing 324$	≥ 3.7		30		EI 120 C/U E 180 C/U	
	$\leq \varnothing 324$	≥ 6.3				EI 120 C/U E 240 C/U	

B.1.16 Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated mineral wool

B.1.16.2 Copper and steel pipes - Stone wool LI 400 / CI





Drawing: RF.E-CU-MM2.7.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Stone wool (≥ 80 kg/m ³)	25	LI 400 / CI	EI 180 C/U	
	$\leq \varnothing 54$	≥ 1.5				EI 240 C/U	
(Stainless) Steel / cast iron	$\leq \varnothing 40$	≥ 1.0				EI 120 C/U	
	$\leq \varnothing 114.3$	≥ 3.6				E 180 C/U	
	$\leq \varnothing 40$	≥ 1.0		30		EI 240 C/U	
	$\leq \varnothing 219$	≥ 4.0				EI 120 C/U	
						E 180 C/U	

B.1.16 Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated mineral wool



B.1.16.3 Copper and steel pipes - Glass wool LI 400 / Cl

Bottom view




Drawing: RF.E-ST-MM2.7.20.LI

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
(Stainless) Steel / cast iron	≤ Ø 40	≥ 2.0	Isover Climclover Glass wool (≥ 33 kg/m ³)	25	LI 400 / Cl	EI 120 C/U
	≤ Ø 114.3	≥ 3.6				EI 90 C/U
	≤ Ø 219	≥ 4.0		30		E 120 C/U EI 60 C/U E 120 C/U

B.1.17**Multimortar - ≥ 100 mm - Metal pipes insulated elastomer****B.1.17.1****Copper and steel pipes - Elastomer LI 300 / CI - Multicollar Slim**

Drawing: RF.E-MC30-ST-MM1.2.22

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
(Stainless) Steel / cast iron	$\leq \varnothing 114.3$	≥ 3.6	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	32	LI 300 / CI	Multicollar Slim	EI 90 C/U

B.1.17**Multimortar - ≥ 100 mm - Metal pipes insulated elastomer****B.1.17.2****Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap**

Drawing: RF.E-CU-MW-MM1.2.22



Services	Dimensions (mm)		Insulation			Product	Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
Copper / (stainless) steel / cast iron	≤ Ø 12	≥ 1.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	11	LS 400 / CS	Multiwrap (1 layer)	EI 180 C/U E 240 C/U	
	≤ Ø 40	≥ 2.0		11 - 19			EI 90 C/U E 240 C/U	
(Stainless) Steel / cast iron	≤ Ø 168.3			13 - 19			EI 180 C/U E 240 C/U	
		≥ 4.5		19	CS		EI 45 C/U E 240 C/U	
					LS 400 / CS		EI 120 C/U E 240 C/U	
							EI 90 C/U E 240 C/U	

B.1.17**Multimortar - ≥ 100 mm - Metal pipes insulated elastomer****B.1.17.2****Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap**

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	≤ Ø 12	≥ 1.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	11	LS 400 / CS	Multiwrap (2 layers)	EI 120 C/U E 240 C/U
(Stainless) Steel / cast iron				11 - 38			EI 90 C/U
Copper / (stainless) steel / cast iron				25			EI 180 C/U
(Stainless) Steel / cast iron				25 - 38			EI 90 C/U
Copper / (stainless) steel / cast iron				13.5 - 28.5			EI 45 C/U E 90 C/U
(Stainless) Steel / cast iron				28.5 - 38			EI 120 C/U E 180 C/U
Copper / (stainless) steel / cast iron	≤ Ø 54	≥ 1.5	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	25	CS	Multiwrap (3 layers)	EI 30 C/U E 120 C/U
(Stainless) Steel / cast iron				50			EI 60 C/U E 120 C/U
(Stainless) Steel / cast iron				50			EI 240 C/U EI 45 C/U E 240 C/U
(Stainless) Steel / cast iron	≤ Ø 40	≥ 1.0	CS	CS	CS	Multiwrap (3 layers)	EI 120 C/U E 240 C/U
(Stainless) Steel / cast iron	≤ Ø 324	≥ 6.3					EI 120 C/U E 240 C/U



B.1.17**Multimortar - ≥ 100 mm - Metal pipes insulated elastomer****B.1.17.3****Copper and steel pipes - ArmaFlex Protect LS 400 / CS**

Bottom view




Drawing: RF.E-CU-MM1.2.22

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5		25		

B.1.18**Multimortar - ≥ 150 mm - Metal pipes insulated elastomer****B.1.18.1****Copper and steel pipes - Elastomer LI 300 / CI - Multicollar Slim**

Drawing: RF.E-MC30-ST-MM1.3.22

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
(Stainless) Steel / cast iron	$\leq \varnothing 114.3$	≥ 3.6	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	32	LI 300 / CI	Multicollar Slim	EI 90 C/U



B.1.18**Multimortar - ≥ 150 mm - Metal pipes insulated elastomer****B.1.18.2****Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap**

Drawing: RF.E-CU-MW-MM1.3.22

Services	Dimensions (mm)		Insulation			Product	Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
Copper / (stainless) steel / cast iron	$\leq \emptyset 12$	≥ 1.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	11	LS 400 / CS	Multiwrap (1 layer)	EI 180 C/U E 240 C/U	
	$\leq \emptyset 40$			11 - 19			EI 90 C/U E 240 C/U	
	$\leq \emptyset 168.3$	≥ 2.0		13 - 19			EI 180 C/U E 240 C/U	
(Stainless) Steel / cast iron	$\leq \emptyset 168.3$	≥ 4.5		19	CS	EI 45 C/U E 240 C/U	EI 120 C/U E 240 C/U	
					LS 400 / CS		EI 90 C/U E 240 C/U	

B.1.18**Multimortar - ≥ 150 mm - Metal pipes insulated elastomer****B.1.18.2****Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap**

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	≤ Ø 12	≥ 1.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	11	LS 400 / CS	Multiwrap (2 layers)	EI 120 C/U E 240 C/U
(Stainless) Steel / cast iron				11 - 38			EI 90 C/U
Copper / (stainless) steel / cast iron				25			EI 180 C/U
				25 - 38			EI 90 C/U
				13.5 - 28.5			EI 45 C/U E 90 C/U
				28.5 - 38			EI 120 C/U E 180 C/U
	≤ Ø 54	≥ 1.5	25	50	CS	Multiwrap (3 layers)	EI 30 C/U E 120 C/U
							EI 60 C/U E 120 C/U
							EI 240 C/U
							EI 45 C/U E 240 C/U
	≤ Ø 324	≥ 6.3					EI 120 C/U E 240 C/U



B.1.18**Multimortar - ≥ 150 mm - Metal pipes insulated elastomer****B.1.18.3****Copper and steel pipes - ArmaFlex Protect LS 400 / CS**Bottom view

Drawing: RF.E-CU-MM1.3.22

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5		25		

B.1.19 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer

B.1.19.1 Copper and steel pipes - Elastomer LI 300 / CI - Multicollar Slim





Drawing: RF.E-ST-MM2.5.22

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
(Stainless) Steel / cast iron	$\leq \varnothing 114.3$	≥ 3.6	ArmaFlex (min. class B-s3, d0 B _L -s3, d0)	32	LI 300 / CI	Multicollar Slim	EI 90 C/U

B.1.19 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer

B.1.19.2 Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap

Bottom view




Drawing: RF.E-ST-MW2-MM2.5.22

Services	Dimensions (mm)		Insulation			Product	Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
Copper / (stainless) steel / cast iron	$\leq \text{Ø} 12$	≥ 1.0	ArmaFlex (min. class B-s3, d0 B_L -s3, d0)	11	LS 400 / CS	Multiwrap (2 layers)	EI 120 C/U	
				11 - 38			E 180 C/U	
	$\leq \text{Ø} 54$	≥ 1.5		13.5 - 38			EI 90 C/U	
				28.5 - 38			EI 45 C/U	
				13 - 19			E 90 C/U	
							EI 90 C/U	
(Stainless) Steel / cast iron	$\leq \text{Ø} 168.3$	≥ 4.5					EI 45 C/U	
							E 120 C/U	

B.1.19 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer

B.1.19.3 Copper and steel pipes - Elastomer LS 400 / CS - Multisealant GR



Drawing: RF-CU-G1.18-MM2.5.22

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	ArmaFlex AF (min. class B-s3, d0 B _L -s3, d0)	8.5	LS 400 / CS	Multisealant GR ≥ 10 x 20 (wxd)	EI 60 C/U E 120 C/U	
				8.5 - 33.5			EI 60 C/U E 90 C/U	
	≤ Ø 54	≥ 1.5		13.5	CS		EI 120 C/U	
				13.5 - 38	LS 400 / CS		EI 90 C/U E 120 C/U	
	≤ Ø 26.9	≥ 2.3		8.5 - 35			EI 120 C/U	
				15	CS		EI 90 C/U E 120 C/U	
(Stainless) Steel / cast iron	≤ Ø 114.3	≥ 3.6		15 - 43	LS 400 / CS			

B.1.19 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer



B.1.19.3 Copper and steel pipes - Elastomer LS 400 / CS - Multisealant GR

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	ArmaFlex NH (min. class D-s3, d0 D _L -s3, d0)	9 - 25	LS 400 / CS	Multisealant GR ≥ 10 x 20 (wxd)	EI 120 C/U
	≤ Ø 54	≥ 1.5		13			EI 90 C/U
	≤ Ø 26.9	≥ 2.3		13 - 25			EI 120 C/U
	≤ Ø 114.3	≥ 3.6		9 - 25			EI 120 C/U
				19 - 25			

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification		
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration				
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	ArmaFlex Ultima (min. class B-s1, d0 B _L -s1, d0)	9 - 25	LS 400 / CS	Multisealant GR ≥ 10 x 20 (wxd)	EI 60 C/U E 120 C/U		
				25 - 32			EI 90 C/U E 120 C/U		
	≤ Ø 54	≥ 1.5		13 - 32			EI 60 C/U E 120 C/U		
				13 - 32	CS		EI 90 C/U E 120 C/U		
				32	LS 400 / CS		EI 90 C/U		
(Stainless) Steel / cast iron	≤ Ø 26.9	≥ 2.3		9 - 25			EI 60 C/U E 90 C/U		
				25			EI 90 C/U E 120 C/U		
	≤ Ø 114.3	≥ 3.6		13			EI 60 C/U E 120 C/U		
				13 - 32					

B.1.19 Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes insulated elastomer

B.1.19.4 Copper and steel pipes - ArmaFlex Protect LS 400 / CS





Drawing: RF.E-CU-MM2.5.22

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5		25		

B.1.20 Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated elastomer

B.1.20.1 Copper and steel pipes - Elastomer LI 300 / CI - Multicollar Slim





Drawing: RF.E-MC30-ST-MM2.7.22

Services	Dimensions (mm)		Insulation			Product	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
(Stainless) Steel / cast iron	≤ Ø 114.3	≥ 3.6	ArmaFlex (min. class B-s3, d0 B _L -s3, d0)	32	LI 300 / CI	Multicollar Slim	EI 90 C/U

B.1.20 Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated elastomer

B.1.20.2 Copper and steel pipes - Elastomer LS 400 / CS - Multiwrap





Drawing: RF.E-CU-MW-MM2.7.22

Services	Dimensions (mm)		Insulation			Product	Classification				
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration						
Copper / (stainless) steel / cast iron	≤ Ø 12	≥ 1.0	ArmaFlex (min. class B-s3, d0 B _L -s3, d0)	11	LS 400 / CS	Multiwrap (2 layers)	EI 120 C/U				
				11 - 38			E 180 C/U				
	≤ Ø 54	≥ 1.5		13.5 - 38			EI 90 C/U				
				28.5 - 38			EI 45 C/U				
	≤ Ø 168.3	≥ 4.5		13 - 19			E 90 C/U				
							EI 90 C/U				
(Stainless) Steel / cast iron							EI 45 C/U				
							E 120 C/U				

B.1.20 Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated elastomer

B.1.20.3 Copper and steel pipes - Elastomer LS 400 / CS - Multisealant GR

Bottom view



Drawing: RF.E-CU-G1.18-MM2.7.22

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification	
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	ArmaFlex (min. class B-s3, d0 B _L -s3, d0)	8.5	LS 400 / CS	Multisealant GR ≥ 10 x 20 (wxd)	EI 60 C/U E 120 C/U	
				8.5 - 33.5			EI 60 C/U E 90 C/U	
	≤ Ø 54	≥ 1.5		13.5	CS		EI 120 C/U	
				13.5 - 38	LS 400 / CS		EI 90 C/U E 120 C/U	
	≤ Ø 26.9	≥ 2.3		8.5 - 35			EI 120 C/U	
				15	CS		EI 90 C/U E 120 C/U	
(Stainless) Steel / cast iron	≤ Ø 114.3	≥ 3.6		15 - 43	LS 400 / CS			



B.1.20 Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated elastomer
B.1.20.3 Copper and steel pipes - Elastomer LS 400 / CS - Multisealant GR

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration		
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	ArmaFlex NH (min. class D-s3, d0 D _L -s3, d0)	9 - 25	LS 400 / CS	Multisealant GR ≥ 10 x 20 (wxd)	EI 120 C/U
	≤ Ø 54	≥ 1.5		13			EI 90 C/U
	≤ Ø 26.9	≥ 2.3		13 - 25			EI 120 C/U
	≤ Ø 114.3	≥ 3.6		9 - 25			EI 120 C/U
				19 - 25			

Services	Pipe dimensions (mm)		Insulation			Sealing (mm)	Classification		
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration				
Copper / (stainless) steel / cast iron	≤ Ø 22	≥ 1.0	ArmaFlex Ultima (min. class B-s1, d0 B _L -s1, d0)	9 - 25	LS 400 / CS	Multisealant GR ≥ 10 x 20 (wxd)	EI 60 C/U E 120 C/U		
				25 - 32			EI 90 C/U E 120 C/U		
	≤ Ø 54	≥ 1.5		13 - 32			EI 60 C/U E 120 C/U		
				13 - 32	CS		EI 90 C/U E 120 C/U		
				32	LS 400 / CS		EI 90 C/U		
(Stainless) Steel / cast iron	≤ Ø 26.9	≥ 2.3		9 - 25			EI 60 C/U E 90 C/U		
				25			EI 90 C/U E 120 C/U		
	≤ Ø 114.3	≥ 3.6		13			EI 60 C/U E 120 C/U		
				13 - 32					



B.1.20 Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes insulated elastomer

B.1.20.4 Copper and steel pipes - ArmaFlex Protect LS 400 / CS





Drawing: RF.E-CU-MM2.7.22

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	ArmaFlex Protect	20 - 25	LS 400 / CS	EI 120 C/U
	$\leq \varnothing 54$	≥ 1.5		25		

B.1.21**Multimortar - ≥ 100 mm - Metal pipes uninsulated****B.1.21.1****Copper and steel pipes - Multimastic SP**Bottom view



Drawing: RF.E-CU-SPC-MM1.2.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0	Multimastic SP	1.5 WFT	LI 200	EI 20 C/U, E 90 C/U
(Stainless) steel / cast iron	$\leq \varnothing 22$	≥ 1.0				EI 30 C/U, E 90 C/U
	$\leq \varnothing 42.4$	≥ 3.2				

B.1.21**Multimortar - ≥ 100 mm - Metal pipes uninsulated****B.1.21.2****Copper and steel pipes - Multisealant GR**Bottom view



Drawing: RF.E-CU-GRC-MM1.2.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0	Multisealant GR	1.5 WFT	LI 200	EI 60 C/U, E 90 C/U
(Stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0				
	$\leq \varnothing 42.4$	≥ 3.2				

B.1.21**Multimortar - ≥ 100 mm - Metal pipes uninsulated****B.1.21.3****Copper and steel pipes - Multidisc**



Drawing: RF.E-CU-M1-MM1.2.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0	Multidisc bottom of floor	EI 60 U/C

B.1.22**Multimortar - ≥ 150 mm - Metal pipes uninsulated****B.1.22.1****Copper and steel pipes - Multimastic SP**Bottom view



Drawing: RF.E-CU-SPC-MM1.3.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \emptyset 22$	≥ 1.0	Multimastic SP	1.5 WFT	LI 200	EI 20 C/U, E 90 C/U
(Stainless) steel / cast iron	$\leq \emptyset 22$	≥ 1.0				EI 30 C/U, E 90 C/U
	$\leq \emptyset 42.4$	≥ 3.2				

B.1.22**Multimortar - ≥ 150 mm - Metal pipes uninsulated****B.1.22.2****Copper and steel pipes - Multimastic SP - either side**Bottom view



Drawing: RF.E-CU-SPC.2-MM1.3.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
(Stainless) steel / cast iron	$\leq \emptyset 35$	≥ 2.0	Multimastic SP	1.5 WFT	LI 200 either side	EI 120 C/U

B.1.22**Multimortar - ≥ 150 mm - Metal pipes uninsulated****B.1.22.3****Copper and steel pipes - Multisealant GR**Bottom view



Drawing: RF.E-CU-GRC-MM1.3.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0	Multisealant GR	1.5 WFT	LI 200	EI 60 C/U, E 90 C/U
(Stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0				
	$\leq \varnothing 42.4$	≥ 3.2				

B.1.22**Multimortar - ≥ 150 mm - Metal pipes uninsulated****B.1.22.4****Copper and steel pipes - Multidisc**Bottom view



Drawing: RF.E-CU-M1-MM1.3.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \emptyset 15$	≥ 1.0	Multidisc bottom of floor	EI 60 U/C

B.1.22**Multimortar - ≥ 150 mm - Metal pipes uninsulated****B.1.22.5****Copper and steel pipes - Multitherm Bandage - either side**Top view



Drawing: RF.E-CU-B3-MM1.3.10

Services	Pipe dimensions (mm)		Multitherm Bandage	Classification
	Outer dimension	Wall thickness		
(Stainless) Steel / cast iron	$\leq \varnothing 40$	≥ 2.0	LI 150 one layer top of floor	EI 120 C/U
Copper / (stainless) steel / cast iron	$\leq \varnothing 35$	≥ 1.1	LI 150 two layers top of floor	
(Stainless) Steel / cast iron	$\leq \varnothing 60$	≥ 1.5		

B.1.23**Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes uninsulated****B.1.23.1****Copper and steel pipes - Multimastic SP**Bottom view



Drawing: RF.E-CU-SPC-MM2.5.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \emptyset 22$	≥ 1.0	Multimastic SP	1.5 WFT	LI 200	EI 20 C/U, E 90 C/U
(Stainless) steel / cast iron	$\leq \emptyset 22$	≥ 1.0				EI 30 C/U, E 90 C/U
	$\leq \emptyset 42.4$	≥ 3.2				

B.1.23**Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes uninsulated****B.1.23.2****Copper and steel pipes - Multisealant GR**Bottom view



Drawing: RF.E-CU-GRC-MM2.5.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0	Multisealant GR	1.5 WFT	LI 200	EI 60 C/U, E 90 C/U
(Stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0				
	$\leq \varnothing 42.4$	≥ 3.2				

B.1.23**Multimortar + Multimastic FB - ≥ 100 mm - Metal pipes uninsulated****B.1.23.3****Copper and steel pipes - Multidisc**Bottom view



Drawing: RF.E-CU-M1-MM2.5.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \varnothing 15$	≥ 1.0	Multidisc bottom of floor	EI 60 U/C

B.1.24**Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes uninsulated****B.1.24.1****Copper and steel pipes - Multimastic SP**Bottom view



Drawing: RF.E-CU-SPC-MM2.2.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \emptyset 22$	≥ 1.0	Multimastic SP	1.5 WFT	LI 200	EI 90 C/U, E 120 C/U
(Stainless) steel / cast iron	$\leq \emptyset 26.9$	≥ 2.3				EI 120 C/U
	$\leq \emptyset 22$	≥ 1.0				EI 90 C/U, E 120 C/U
	$\leq \emptyset 42.4$	≥ 3.2				

B.1.24**Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes uninsulated****B.1.24.2****Copper and steel pipes - Multisealant GR**Bottom view



Drawing: RF.E-CU-GRC-MM2.2.10

Services	Pipe dimensions (mm)		Insulation			Classification
	Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration	
Copper / (stainless) steel / cast iron	$\leq \emptyset 15$	≥ 1.0	Multisealant GR	1.5 WFT	LI 200	EI 60 C/U, E 90 C/U
(Stainless) steel / cast iron	$\leq \emptyset 15$	≥ 1.0				EI 120 C/U
	$\leq \emptyset 42.4$	≥ 3.2				

B.1.24**Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes uninsulated****B.1.24.3****Copper and steel pipes - Multidisc**Bottom view


Drawing: RF.E-CU-M1-MM2.7.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \emptyset 15$	≥ 1.0	Multidisc bottom of floor	EI 60 U/C

B.1.24**Multimortar + Multimastic FB - ≥ 150 mm - Metal pipes uninsulated****B.1.24.4****Copper and steel pipes - Multitherm Bandage**

Drawing: RF.E-CU-B2-MM2.7.10

Services	Pipe dimensions (mm)		Product	Classification
	Outer dimension	Wall thickness		
Copper / (stainless) steel / cast iron	$\leq \emptyset 54$	≥ 1.5	LI 150 two layers (two wires) + LI 300 one layer (two wires)	EI 90 C/U, E 120 C/U

B.1.25**Multimortar - ≥ 100 mm - Busbars****B.1.25.1****Single busbar**Side view


Drawing: RF.E-1BB-MM1.2.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


B.1.25 Multimortar - \geq 100 mm - Busbars

B.1.25.1 Single busbar

Bottom view



Drawing: RF.E-1BB-MM1.2.10

B.1.25**Multimortar - ≥ 100 mm - Busbars****B.1.25.2****Multiple busbars**


Drawing: RF.E-2BB-MM2.2.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500$ mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120

B.1.25 Multimortar - \geq 100 mm - Busbars

B.1.25.2 Multiple busbars


Bottom view



Drawing: RF.E-2BB-MM2.2.10

B.1.26 Multimortar - ≥ 150 mm - Busbars

B.1.26.1 Single busbar




Drawing: RF.E-1BB-MM1.3.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250 \text{ mm}$	max. $6 \times \leq 200 \text{ mm}$ width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120

B.1.26 Multimortar - ≥ 150 mm - Busbars

B.1.26.1 Single busbar


Bottom view



Drawing: RF.E-1BB-MM1.2.10

B.1.26**Multimortar - ≥ 150 mm - Busbars****B.1.26.2****Multiple busbars**

Side view




Drawing: RF.E-2BB-MM1.3.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500$ mm	max. $6 \times \leq 200$ mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


B.1.26 Multimortar - \geq 150 mm - Busbars

B.1.26.2 Multiple busbars

Bottom view



Drawing: RF.E-2BB-MM1.3.10

B.1.27**Multimortar + Multimastic FB - ≥ 100 mm - Busbars****B.1.27.1****Single busbar**Side view

Drawing: RF.E-1BB-MM2.5.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. $6 \times \leq 200$ mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


B.1.27

Multimortar + Multimastic FB - ≥ 100 mm - Busbars


B.1.27.1

Single busbar

Bottom view



Drawing: RF.E-1BB-MM2.5.10

B.1.27**Multimortar + Multimastic FB - ≥ 100 mm - Busbars****B.1.27.2****Multiple busbars**

Drawing: RF.E-2BB-MM2.5.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500$ mm	max. $6 \times \leq 200$ mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


B.1.27

Multimortar + Multimastic FB - ≥ 100 mm - Busbars


B.1.27.2

Multiple busbars

Bottom view



Drawing: RF.E-2BB-MM2.5.10

B.1.28**Multimortar + Multimastic FB - ≥ 150 mm - Busbars****B.1.28.1****Single busbar**

Drawing: RF.E-1BB-MM2.7.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Single busbar	$\leq 150 \times 250$ mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


B.1.28

Multimortar + Multimastic FB - ≥ 150 mm - Busbars


B.1.28.1

Single busbar

Bottom view



Drawing: RF.E-1BB-MM2.7.10

B.1.28**Multimortar + Multimastic FB - ≥ 150 mm - Busbars****B.1.28.2****Multiple busbars**

Drawing: RF.E-2BB-MM2.7.10

Services	Service dimensions		Insulation			Classification
	Outside dimension	Conductors	Type	Thickness (mm)	Configuration	
Double busbar	$\leq 150 \times 500$ mm	max. 6 x ≤ 200 mm width (per busbar)	Multimastic FB	50	LI 400 / CI	EI 120


B.1.28

Multimortar + Multimastic FB - ≥ 150 mm - Busbars



B.1.28.2

Multiple busbars

Bottom view




Drawing: RF.E-2BB-MM2.7.10

B.1.29**Multimortar + Multimastic FB - ≥ 150 mm - Gas pipes****B.1.29.1****Corrugated stainless steel tube gas (CSST) pipes - Multicollar Slim - Multitherm Bandage**



Drawing: RF.E-CT-GFS-MM2.2.10

Services	Number of pipes	Product	Sealing (mm)	Classification
CFS CSST gas pipe ≤ Ø 20 mm in wire mesh cable tray	≤ 4	Multicollar Slim bottom of floor	LI 150 one layer top of floor	EI 120 U/C
CFS CSST gas pipe ≤ Ø 41 mm in wire mesh cable tray	≤ 4			

B.1.29**Multimortar + Multimastic FB - ≥ 150 mm - Gas pipes****B.1.29.2****Corrugated stainless steel tube gas (CSST) pipes - Multicollar Slim - Multitherm Bandage**


Drawing: RF.E-GFS2-MM2.2.1

Services	Number of pipes	Product	Sealing (mm)	Classification
CFS CSST gas pipe ≤ Ø 41 mm	≤ 2	Mulcol® Multicollar Slim bottom of floor	LI 150 one layer top of floor	EI 120 U/C

B.1.30**Multimortar - ≥ 150 mm - Gas pipes****B.1.30.1****Corrugated stainless steel tube gas (CSST) pipes - Multicollar Slim - Multitherm Bandage**



Drawing: RF.E-CT-GFS-MC30-MM1.3.10

Services	Number of pipes	Product	Sealing (mm)	Classification
CFS CSST gas pipe ≤ Ø 20 mm in wire mesh cable tray	≤ 4	Multicollar Slim bottom of floor	LI 150 one layer top of floor	EI 120 U/C
CFS CSST gas pipe ≤ Ø 41 mm in wire mesh cable tray	≤ 4			

B.1.30**Multimortar - ≥ 150 mm - Gas pipes****B.1.30.2****Corrugated stainless steel tube gas (CSST) pipes - Multicollar Slim - Multitherm Bandage**

Drawing: RF.E-GFS2-MC30-MM1.3.10

Services	Number of pipes	Product	Sealing (mm)	Classification
CFS CSST gas pipe ≤ Ø 41 mm	≤ 2	Multicollar Slim bottom of floor	LI 150 one layer top of floor	EI 120 U/C



B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.1****Cables - Multifoam 2K**

Drawing: RFmk.E-EC21-MF.1.31

Services	Sealing (mm)	Classification
Cables ≤ Ø 21 mm with plastic cast-in sleeve	Multifoam 2K ≥ 12.5 x 100 (wxd)	EI 90, E 120



B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.2****Cables - Multisealant GR**

Top view





Drawing: RF-EC21-G3.12.10

Services	Pipe dimensions (mm)		Sealing (mm)	Backing	Classification
	Outer dimension				
Cables ≤ Ø 21 mm	with plastic cast-in sleeve	≤ Ø 50	Multisealant GR ≥ 10 x 20 (wxd)	50 mm stone wool (≥ 33 kg/m³)	EI 120

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.3****Multiple cables - Multifoam 2K**



Drawing: Rfmk.E-ECB40-MF.1.31

Services	Sealing (mm)	Classification
Cable bundle ≤ Ø 40 mm ≤ 8 cables with plastic cast-in sleeve	Multifoam 2K ≥ 3 x 100 (wdx)	EI 60

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.4****Multiple cables - Multisealant GR**



Drawing: RF.E-ECB-G3.12.10

Services	Pipe dimensions (mm)		Sealing (mm)	Backing	Classification
	Outer dimension				
Bundle (telecommunication-) cables ≤ 40 cables	with plastic cast-in sleeve	≤ Ø 75	Multisealant GR ≥ 10 x 20 (wxd)	50 mm stone wool (≥ 33 kg/m³)	EI 120

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.5****Flexible conduit with cables - Multifoam 2K**



Drawing: RFmk.E-ECH63-MF.1.31

Services	Pipe dimensions (mm)		Sealing (mm)	Classification
	Outer dimension			
Bundle cables ≤ 24 cables	with plastic cast-in sleeve	≤ Ø 110	Multifoam 2K ≥ 21.5 x 100 (wxd)	EI 90 C/U, E 120 C/U
	Ribbed PE conduit	≤ Ø 63		

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.6****Flexible conduit with cables - Multisealant GR**



Drawing: RF.E-ECH63-G3.16.30

Services	Pipe dimensions (mm)		Sealing (mm)	Backing	Classification
	Outer dimension				
Bundle (telecommunication)-cables ≤ 13 cables	with plastic cast-in sleeve	≤ Ø 90	Multisealant GR ≥ 10 x 20 (wxd)	50 mm stone wool (≥ 33 kg/m³)	EI 120
	Ribbed PE conduit (LS 200 / CS)	≤ Ø 63			

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.7****Multilayer pipes (MLC) - Multifoam 2K**



Drawing: Rfmk.E-MLA-MF.1.31

Services	Pipe dimensions (mm)		Sealing (mm)	Classification
	Outer dimension	Wall thickness		
Multilayer pipes (MLC) with plastic cast-in sleeve	≤ Ø 40	3.0 - 3.5	Multifoam 2K ≥ 16.5 x 100 (wxd)	EI 90 U/C, E 120 U/C

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.8****Multilayer pipes (MLC) - PE foam insulation LS 50 / CS - Multisealant GR**



Drawing: RF.E-pr_MLA-G3.4.10

Services		Pipe dimensions (mm)		Insulation			Sealing (mm)	Backing	Classification
		Outer dimension	Wall thickness	Type	Thickness (mm)	Configuration			
Multilayer pipes (MLC)	with or without plastic cast-in sleeve ≤ Ø 90	≤ Ø 35	3.0	PE foam	≤ 6	LS 50 / CS LI 50 / CI	Multisealant GR ≥ 10 x 20 (wxd)	50 mm stone wool (≥ 33 kg/m³)	EI 120 U/C

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.9****Multilayer pipes (MLC) - Multisealant GR - Multitherm Bandage**



Drawing: RF.E-MLA-G3.4.10

Services	Pipe dimensions (mm)		Sealing (mm)	Backing	Multitherm Bandage	Classification
	Outer dimension	Wall thickness				
Multilayer pipes (MLC) with or without plastic cast-in sleeve ≤ Ø 75 mm	≤ Ø 40	3.5	Multisealant GR ≥ 10 x 20 (wxd)	50 mm stone wool (≥ 33 kg/m³)	LI 150 one layer top of floor	EI 120 U/C

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.10****Copper and steel pipes - Multifoam 2K - Multitherm Bandage**


Drawing: RFmk.E-CU-B3-MF.1.31

Services	Pipe dimensions (mm)		Sealing (mm)	Multitherm Bandage	Classification
	Outer dimension	Wall thickness			
Copper / (stainless) steel / cast iron	with plastic cast-in sleeve	≤ Ø 35	1.0	Multifoam 2K ≥ 12 x 100 (wxd)	LI 150 two layers top of floor (two wires) EI 90 C/U E 120 C/U

B.1.31**Multimortar - ≥ 150 mm - Electrical room services****B.1.31.11****Copper and steel pipes - Multisealant GR - Multitherm Bandage**

Drawing: RFmk.E-CU-MM1-B3-G3.4.10

Services	Pipe dimensions (mm)		Sealing (mm)	Backing	Multitherm Bandage	Classification
	Outer dimension	Wall thickness				
Copper / (stainless) steel / cast iron	with plastic cast-in sleeve ≤ Ø 50 mm	≤ Ø 35	≥ 1.5	Multisealant GR ≥ 15 x 20 (wxd)	50 mm stone wool (≥ 33 kg/m³)	LI 150 two layers top of floor EI 120 C/U

C.1**Flexible and rigid wall - General****C.1.1****Mutual distances & distance to first support****Mutual distances Mixed Penetration Seal – Mulcol® Multimortar**


- a_1 Distance between cables/cable trays and metal pipes
- a_2 Distance between cables/cable trays and plastic pipes
- a_3 Distance between metal pipes and plastic pipes
- a_4 Distance between plastic pipes
- a_5 Distance between metal pipes with non-combustible insulation
- a_6 Distance between cable trays
- a_7 Distance between plastic pipes and pipes with combustible insulation
- a_8 Distance between pipes with non-combustible insulation and pipes with combustible insulation
- a_9 Distance between cables/cable trays and pipes with combustible insulation
- a_{10} Distance between cables stacked together or in a row
- b_1 Distance between cables/cable trays and the upper seal edge
- b_2 Distance between cables/cable trays and the side seal edge
- b_3 Distance between cables/cable tray and the lower seal edge
- b_4 Distance between metal pipes and all seal edges
- b_5 Distance between plastic pipes and all seal edges

Service support construction

First support for all services at 450 mm, except cable trays at 250 mm.

C.1.2 Flexible and rigid wall - Maximum seal dimensions

C.1.2.1 Multimortar - ≥ 100 mm




Drawing: FW.E-BS-MM1.2.10

Services	Classification
Maximum seal size 1500 x 2500 mm (width x height or height x width) With a maximum surface of 3 m ²	EI 120
Maximum circular seal size Ø 1954 mm	
Maximum seal size 1200 x 2000 mm (width x height or height x width) With a maximum surface of 2.4 m ²	EI 180
Maximum circular seal size Ø 1748 mm	

C.1.2 Flexible and rigid wall - General - Maximum seal dimensions

C.1.2.2 Multimortar + Multimastic FB system - ≥ 100 mm




Drawing: FW.E-BS-MM2.5.10

Services	Classification
Maximum seal size 1500 x 2500 mm (width x height or height x width) With a maximum surface of 3 m ²	EI 60
Maximum circular seal size Ø 1954 mm	
Maximum seal size 1200 x 1200 mm (width x height or height x width) With a maximum surface of 1.44 m ²	EI 60, E 90
Maximum circular seal size Ø 1354 mm	
Maximum seal size 625 x 750 mm (width x height or height x width) With a maximum surface of 0.38 m ²	EI 120
Maximum circular seal size Ø 691 mm	


C.1.2 Flexible and rigid wall - General - Maximum seal dimensions

C.1.2.3 Multimortar 25 mm + Multimastic FB + Multimortar 25 mm - ≥ 100 mm



Drawing: FW.E-BS-MM3.4.10

Services	Classification
Maximum seal size 1500 x 2500 mm (width x height or height x width) With a maximum surface of 3 m ²	EI 60
Maximum circular seal size Ø 1954 mm	
Maximum seal size 1200 x 1200 mm (width x height or height x width) With a maximum surface of 1.44 m ²	EI 60, E 90
Maximum circular seal size Ø 1354 mm	
Maximum seal size 625 x 750 mm (width x height or height x width) With a maximum surface of 0.38 m ²	EI 120
Maximum circular seal size Ø 691 mm	

C.2**Rigid floor - General****C.2.1****Mutual distances & distance to first support****Mutual distances Mixed Penetration Seal – Mulcol® Multimortar**


- a₁ Distance between cables/cable trays and metal pipes
- a₂ Distance between cables/cable trays and plastic pipes
- a₃ Distance between metal pipes and plastic pipes
- a₄ Distance between plastic pipes
- a₅ Distance between metal pipes with non-combustible insulation
- a₆ Distance between cable trays
- a₇ Distance between plastic pipes and pipes with combustible insulation
- a₈ Distance between pipes with non-combustible insulation and pipes with combustible insulation
- a₉ Distance between cables/cable trays and pipes with combustible insulation
- a₁₀ Distance between cables stacked together or in a row
- b₁ Distance between cables/cable trays and the upper seal edge
- b₂ Distance between cables/cable trays and the side seal edge
- b₃ Distance between cables/cable tray and the lower seal edge
- b₄ Distance between metal pipes and all seal edges
- b₅ Distance between plastic pipes and all seal edges

Service support construction

First support for all services at 450 mm, except cable trays at 250 mm.


C.2.2 Rigid floor - General - Maximum seal dimensions

C.2.2.1 Multimortar - ≥ 100 mm



Drawing: RF.E-BS-MM1.3.10

Services	Classification
Maximum seal size 1200 x 1000 mm	EI 180
Maximum seal size 8500 x 820 mm	
Maximum circular seal size Ø 1236 mm	
Maximum seal size 1000 x 750 mm	EI 240
Maximum circular seal size Ø 977 mm	


C.2.2**Rigid floor - General - Maximum seal dimensions****C.2.2.2****Multimortar + Multimastic FB system - ≥ 100 mm**

Drawing: RF.E-BS-MM2.5.10

Services	Classification
Maximum seal size 1200 x 1000 mm	
Maximum seal size 8200 x 820 mm	EI 180
Maximum circular seal size Ø 1236 mm	

C.2.2 Rigid floor - General - Maximum seal dimensions

C.2.2.3 Multimortar + Multimastic FB system - ≥ 150 mm



Drawing: RF.E-BS-MM2.2.10

Services	Classification
Maximum seal size 1200 x 1000 mm	EI 180
Maximum seal size 8200 x 820 mm	
Maximum circular seal size Ø 1236 mm	
Maximum seal size 450 x 450 mm	EI 240
Maximum circular seal size Ø 508 mm	

C.3

Wall configurations

C.3.1

Allowed wall configurations

The use of Mulcol® Multimortar is allowed in all double sided flexible wall constructions (with or without insulation) of the same or higher fire resistance classification in accordance with EN 13501-2, with a lining made of gypsum boards (EN 520) or Calcium Silicate boards which are CE marked for the application as lining of flexible wall, if their construction is in accordance with the rules given below.

Field of direct application rules for double-sided flexible wall constructions:

- flexible wall constructions as shown in solutions given in Annex A of this document;
- flexible wall constructions with the same or higher number of board layers of the same or higher board thickness on each side of the wall, with insulation of any type;
- flexible wall constructions with a reduced number of board layers but the same or higher board thickness on each side of the wall as tested, with insulation of any type;
- flexible wall constructions with timber studs, no part of the penetration seal closer than 100 mm to any stud or nogging piece, the cavity closed between the penetration seal and the stud/nogging piece with minimum 100 mm of insulation of class A1 or A2 in accordance with EN 13501-1;
- rigid constructions of an overall thickness equal to or greater than that given in the solutions in Annex A and a minimum density of 350 kg/m³. In case of hollow brick wall the same rules regarding aperture framing apply as for double-sided flexible walls.

Allowed constructions (not limited by):


Flexible walls, fully insulated with any type of insulation.

e.g.:



Double stud walls, separated by ≥ 0 mm, fully insulated with any type of insulation.

e.g.:



C.3

Wall configurations


C.3.1

Allowed wall configurations

Walls with a reduced number of board layers but the same or higher overall lining thickness on each side of the wall as shown in the solutions in Annex A.

Walls with a higher number of board layers, where individual boards are thinner yet the overall lining thickness is at least that of shown in the solutions in Annex A.

e.g.:



Rigid walls with a density of $\geq 350 \text{ kg/m}^3$

e.g.:

